



Three Phase Electrical Test Results Sheet
RECORD ACTUAL TEST RESULTS FOR ALL MEASURABLE RESULTS
PHASE ROTATION = CLOCKWISE OR ANTICLOCKWISE

Maco Electrics Pty Ltd
ABN 18 167 609 005
QLD Lic # 79105
NSW Lic # 252321c

Unit 4/71 Township Drive,
Burleigh Heads QLD 4220
admin@macoelectrics.com
www.macoelectrics.com.au

Page ___ of ___

Project Name	OPUS BROADBEACH	Tested by	J. McManus	Project No	J20160	Equipment Type	Plant or serial Number	Calibration due date
Client / Organization	MPC.	Signature		Licence No	143842	Insulation	MA102	
Address	16-18 CULDESEA AVE BROADBEACH.					Continuity	MA102	
Location (building/ floor etc)	GROUND MSB ROOM.	Board identifier (DB-1/MSB etc)	MSB COMMUNITY	DWG Number		Fault Loop	MA 102	
						RCD	MA 102	

CIRCUIT BREAKER NO.	DRAWING CIRCUIT NO.	NO. OF POINTS	CIRCUIT BREAKER SIZE	NEUTRAL LINK no.	EARTH NO.	CABLE SIZE	EQUIPMENT	EARTH CONTINUITY <0.5Ω	APPLIED VOLTAGE	INSULATION RESISTANCE										POLARITY CONFIRMED [ⓑ]	INTERCONNECTION	EUI	ROTATION CONFIRMED	VISUAL CHECK [ⓑ]	RCD OPERATION			TEST DATE
										mA	INJECT CURRENT %	0 ² ms	180 ² ms															
												TEST TRIP TIME	TEST TRIP TIME															
27			100 ^A	CABLE ZONE	35 ^{mm²}	DB-B1	0.15Ω	1000V	∞	∞	∞	∞	∞	∞	∞	∞	∞	∞	✓	✓		✓	✓	N/A	100% (EL x 1.0)	N/A	N/A	11.11
3.			63 ^A	CABLE ZONE	25 ^{mm²}	DB-L2	0.05Ω	1000V	∞	∞	∞	∞	∞	∞	∞	∞	∞	∞	✓	✓		✓	✓	N/A	100% (EL x 1.0)	N/A	N/A	27.5
4.			63 ^A	CABLE ZONE	16 ^{mm²}	DB-L9	0.28Ω	1000V	∞	∞	∞	∞	∞	∞	∞	∞	∞	∞	✓	✓		✓	✓	N/A	100% (EL x 1.0)	N/A	N/A	7.5
9.			63 ^A	CABLE ZONE	16 ^{mm²}	DB-L21	0.37Ω	1000V	∞	∞	∞	∞	∞	∞	∞	∞	∞	∞	✓	✓		✓	✓	N/A	100% (EL x 1.0)	N/A	N/A	27.5
13			20 ^A	13	13	R. J. J.	FSSB-2	0.22Ω	500V				∞			∞			✓	✓		✓	✓	N/A	100% (EL x 1.0)	N/A	N/A	27.5
14			20 ^A	14	14	R. J. J.	FSSB-3	0.22Ω	500V				∞			∞			✓	✓		✓	✓	N/A	100% (EL x 1.0)	N/A	N/A	27.5
21			50 ^A	21	21		PSSB.																	100% (EL x 1.0)				
																								100% (EL x 1.0)				
																								100% (EL x 1.0)				

I certify by signing above that the electrical installation to the extent it is affected by the electrical work, has been tested to ensure that it is electrically safe and is in accordance with the requirements of the wiring rules and any other standard applying under the electrical safety regulation 2002.