

Energisation or Verification of an Electrical Installation

(AS/NZS 3000:2018 Clause 8.4)

Date of energisation and original verification details are to be recorded and available on site in this accessible record. This also facilitates the process of re-verification at a later date.



Maco Electrics

4/71 Township Drive, Burleigh Heads QLD 4220

[View in Google Docs](#)

SITE / PROJECT OPUS BROADBEACH J20160		Date of Initial Energisation		
Test Organisation or Department MACO ELECTRICS		Electrical Contractor Number 82868		
Name of Electrical Licence Holder Jesse McMahon		Electrical Licence Number 143842	Signature	
Test Equipment Spark-e-mate	Manufacturer Design 2000 Pty Ltd	Model Number Clipsal Cat. No. 493BTLi	Serial Number C014398	Last Calibration 09/07/2020
Job Date 16/12/2020	Result FAIL	Job Notes 113 Units		

IMPORTANT: REFER TO THE APPLICABLE AS/NZS STANDARD WHEN INTERPRETING ANY RESULT

Unit 1

P1

Notes: Kitchen/Lounge

Test Date and Time	Test	Measurement	Notes	Result
18/12/20, 12:53:48 pm	Voltage & Frequency	238V 50.0Hz		Fail
18/12/20, 12:54:08 pm	Powered Earth Continuity	0.07 Ohms		Fail
18/12/20, 12:54:15 pm	Polarity	OK		Pass
18/12/20, 12:54:22 pm	Circuit Connections	OK		Pass
18/12/20, 12:54:47 pm	Powered Fault Loop	0.37 ZsOhms		Fail
18/12/20, 12:54:58 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
18/12/20, 12:55:24 pm	RCD Test	34ms at 30mA (180 degrees)		Pass
18/12/20, 1:01:50 pm	Insulation Resistance	>10 M.Ohms at 250V (A-E)		Fail
18/12/20, 1:02:25 pm	Insulation Resistance	1.08 M.Ohms at 250V (A-N)		Fail
18/12/20, 1:02:52 pm	Circuit Connections	OK		Pass
18/12/20, 1:03:01 pm	Unpowered Fault Loop	>20.00 Ohms		Fail
18/12/20, 1:05:49 pm	Unpowered Earth Continuity	>20.00 Ohms		Fail
18/12/20, 1:06:10 pm	Insulation Resistance	2.89 M.Ohms at 250V (A-E)		Fail
18/12/20, 1:06:22 pm	Circuit Connections	OK		Pass
18/12/20, 1:06:30 pm	Unpowered Fault Loop	>20.00 Ohms		Fail

P2

Notes: Bed/Bath/Laundry

Test Date and Time	Test	Measurement	Notes	Result
18/12/20, 12:42:49 pm	Powered Earth Continuity	0.07 Ohms		Fail
18/12/20, 12:43:02 pm	Polarity	OK		Pass
18/12/20, 12:43:09 pm	Circuit Connections	OK		Pass
18/12/20, 12:43:34 pm	Powered Fault Loop	0.78 ZsOhms		Fail
18/12/20, 12:43:51 pm	RCD Test	38ms at 30mA (90 degrees)		Pass
18/12/20, 12:44:20 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
18/12/20, 12:45:20 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
18/12/20, 12:45:44 pm	Voltage & Frequency	238V 50.0Hz		Fail
18/12/20, 12:46:25 pm	RCD Test	34ms at 30mA (180 degrees)		Pass
18/12/20, 12:51:07 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 1, P2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
18/12/20, 1:03:38 pm	Unpowered Earth Continuity	>20.00 Ohms		Fail
18/12/20, 1:03:55 pm	Insulation Resistance	>10 M.Ohms at 250V (A-E)		Fail
18/12/20, 1:04:11 pm	Insulation Resistance	1.08 M.Ohms at 250V (A-N)		Fail
18/12/20, 1:04:21 pm	Circuit Connections	OK		Pass
18/12/20, 1:04:31 pm	Unpowered Fault Loop	>20.00 Ohms		Fail

Unit 3

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 6:58:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 6:58:26 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 6:58:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 7:10:57 am	Powered Earth Continuity	0.21 Ohms		Pass
6/1/21, 7:18:45 am	Polarity	OK		Pass
6/1/21, 7:18:54 am	RCD Test	38ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 6:55:32 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 6:56:06 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 6:57:31 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 7:12:27 am	Powered Earth Continuity	0.21 Ohms		Pass
6/1/21, 7:19:32 am	Polarity	OK		Pass
6/1/21, 7:20:03 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 6:59:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 6:59:39 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 6:59:54 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
6/1/21, 7:11:30 am	Powered Earth Continuity	0.18 Ohms		Pass
6/1/21, 7:20:33 am	Polarity	OK		Pass
6/1/21, 7:20:40 am	RCD Test	28ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 7:00:47 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 7:01:00 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 7:03:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 7:13:06 am	Powered Earth Continuity	0.19 Ohms		Pass
6/1/21, 7:20:55 am	Polarity	OK		Pass
6/1/21, 7:21:12 am	RCD Test	38ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 7:04:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Fixed
6/1/21, 7:04:14 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Fixed
6/1/21, 7:04:31 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Fixed
6/1/21, 7:14:06 am	Powered Earth Continuity	0.26 Ohms		Fixed
6/1/21, 7:21:43 am	Polarity	OK		Pass
6/1/21, 7:21:51 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 7:04:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 7:05:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 7:05:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 7:17:44 am	Powered Earth Continuity	0.15 Ohms		Pass
6/1/21, 7:23:06 am	Polarity	OK		Pass
6/1/21, 7:23:13 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 4

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 8:37:04 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 8:37:17 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 8:37:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 8:50:54 am	Powered Earth Continuity	0.06 Ohms		Pass
6/1/21, 8:51:03 am	Polarity	OK		Pass
6/1/21, 8:51:10 am	RCD Test	39ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 8:38:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 8:38:17 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 8:38:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 8:54:22 am	Powered Earth Continuity	0.17 Ohms		Pass
6/1/21, 8:54:24 am	Polarity	OK		Pass
6/1/21, 8:54:29 am	RCD Test	39ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 8:39:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 8:39:28 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 8:39:43 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
6/1/21, 8:51:50 am	Powered Earth Continuity	0.08 Ohms		Pass
6/1/21, 8:51:54 am	Polarity	OK		Pass
6/1/21, 8:52:10 am	RCD Test	39ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 8:40:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 8:40:25 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 8:42:11 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 8:55:14 am	Polarity	OK		Pass
6/1/21, 8:56:57 am	Powered Earth Continuity	0.18 Ohms		Fail
6/1/21, 8:57:04 am	RCD Test	39ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 8:42:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 8:43:05 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 8:43:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 8:57:56 am	Powered Earth Continuity	0.17 Ohms		Pass
6/1/21, 8:57:59 am	Polarity	OK		Pass
6/1/21, 8:59:52 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 8:43:51 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 8:44:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 8:44:16 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 9:01:10 am	Powered Earth Continuity	0.12 Ohms		Pass
6/1/21, 9:01:12 am	Polarity	OK		Pass
6/1/21, 9:01:17 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 5

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 9:28:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 9:28:34 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 9:28:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 9:39:34 am	Polarity	OK		Pass
6/1/21, 9:39:53 am	Powered Earth Continuity	0.13 Ohms		Pass
6/1/21, 9:39:59 am	RCD Test	39ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 9:29:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 9:29:33 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 9:29:54 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 9:40:44 am	Powered Earth Continuity	0.05 Ohms		Pass
6/1/21, 9:40:47 am	Polarity	OK		Pass
6/1/21, 9:41:00 am	RCD Test	39ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 9:30:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 9:30:39 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 9:30:54 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
6/1/21, 9:41:36 am	Powered Earth Continuity	0.10 Ohms		Pass
6/1/21, 9:41:41 am	Polarity	OK		Pass
6/1/21, 9:41:47 am	RCD Test	38ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 9:31:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 9:31:44 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 9:32:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 9:43:39 am	Powered Earth Continuity	0.16 Ohms		Pass
6/1/21, 9:43:41 am	Polarity	OK		Pass
6/1/21, 9:43:46 am	RCD Test	38ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 9:32:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 9:32:57 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 9:33:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 9:45:43 am	Polarity	OK		Pass
6/1/21, 9:46:17 am	Powered Earth Continuity	0.09 Ohms		Pass
6/1/21, 9:46:22 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/21, 9:33:57 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 9:34:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 9:34:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 10:02:08 am	Powered Earth Continuity	0.08 Ohms		Pass
6/21, 10:02:10 am	Polarity	OK		Pass
6/21, 10:02:15 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 6

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
3/21, 1:37:54 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 1:38:06 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 1:38:32 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/21, 1:43:14 pm	Powered Earth Continuity	0.06 Ohms		Pass
3/21, 1:43:19 pm	Polarity	OK		Pass
3/21, 1:43:42 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
3/21, 1:44:02 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
3/21, 1:38:50 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 1:39:04 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 1:39:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/21, 2:07:36 pm	Powered Earth Continuity	0.16 Ohms		Pass
3/21, 2:07:38 pm	Polarity	OK		Pass
3/21, 2:08:01 pm	RCD Test	28ms at 30mA (0 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
3/21, 1:39:41 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 1:39:54 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 1:40:05 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
3/21, 1:44:46 pm	Powered Earth Continuity	0.04 Ohms		Pass
3/21, 1:44:49 pm	Polarity	OK		Pass
3/21, 1:45:03 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
3/21, 1:45:15 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
3/21, 1:40:28 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 1:40:39 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 1:40:57 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/21, 1:46:10 pm	Powered Earth Continuity	0.22 Ohms		Pass
3/21, 1:46:12 pm	Polarity	OK		Pass
3/21, 1:46:20 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
3/21, 1:46:50 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
3/21, 1:41:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 1:41:29 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 1:41:42 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass

Unit 6, P2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
3/21, 1:52:10 pm	Powered Earth Continuity	0.35 Ohms		Pass
3/21, 1:52:12 pm	Polarity	OK		Pass
3/21, 1:52:19 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
3/21, 1:52:40 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
3/21, 1:42:00 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 1:42:12 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 1:42:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/21, 1:59:57 pm	Powered Earth Continuity	0.07 Ohms		Pass
3/21, 2:00:00 pm	Polarity	OK		Pass
3/21, 2:00:25 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
3/21, 2:01:30 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 7

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 10:43:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 10:43:16 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 10:43:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 12:01:00 pm	Powered Earth Continuity	0.14 Ohms		Pass
6/1/21, 12:01:04 pm	Polarity	OK		Pass
6/1/21, 12:01:14 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 10:43:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 10:44:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 10:44:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 12:01:51 pm	Powered Earth Continuity	0.14 Ohms		Pass
6/1/21, 12:01:57 pm	Polarity	OK		Pass
6/1/21, 12:02:21 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 10:44:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 10:45:00 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 10:45:17 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
6/1/21, 12:02:50 pm	Powered Earth Continuity	0.08 Ohms		Pass
6/1/21, 12:02:57 pm	Polarity	OK		Pass
6/1/21, 12:03:03 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 10:45:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 10:45:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 10:46:19 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 12:05:09 pm	Powered Earth Continuity	0.13 Ohms		Pass
6/1/21, 12:05:12 pm	Polarity	OK		Pass
6/1/21, 12:05:21 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 10:46:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 10:46:50 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 10:47:12 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 12:07:28 pm	Powered Earth Continuity	0.11 Ohms		Pass
6/1/21, 12:07:30 pm	Polarity	OK		Pass
6/1/21, 12:07:36 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 10:47:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 10:47:51 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 10:48:02 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 12:11:09 pm	Powered Earth Continuity	0.13 Ohms		Pass
6/1/21, 12:11:11 pm	Polarity	OK		Pass
6/1/21, 12:11:17 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 8

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 12:44:36 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 12:44:51 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 12:45:09 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 1:02:19 pm	Powered Earth Continuity	0.06 Ohms		Pass
6/1/21, 1:02:25 pm	Polarity	OK		Pass
6/1/21, 1:02:56 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 12:45:54 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 12:46:07 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 12:46:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 1:03:23 pm	Powered Earth Continuity	0.07 Ohms		Pass
6/1/21, 1:03:29 pm	Polarity	OK		Pass
6/1/21, 1:03:44 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 12:53:15 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 12:53:27 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 12:53:42 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
6/1/21, 1:04:12 pm	Powered Earth Continuity	0.11 Ohms		Pass
6/1/21, 1:04:15 pm	Polarity	OK		Pass
6/1/21, 1:04:22 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 12:54:14 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 12:54:29 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 12:54:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 1:13:41 pm	Powered Earth Continuity	0.08 Ohms		Pass
6/1/21, 1:13:46 pm	Polarity	OK		Pass
6/1/21, 1:13:51 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 12:55:22 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 12:55:36 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 12:56:32 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 1:17:45 pm	Powered Earth Continuity	0.29 Ohms		Pass
6/1/21, 1:17:48 pm	Polarity	OK		Pass
6/1/21, 1:17:53 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 12:57:02 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 12:57:14 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 12:57:25 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/1/21, 1:24:27 pm	Powered Earth Continuity	0.10 Ohms		Pass
6/1/21, 1:24:29 pm	Polarity	OK		Pass
6/1/21, 1:24:34 pm	RCD Test	26ms at 30mA (90 degrees)		Pass

Unit 9

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 1:42:44 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 1:43:02 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 9:36:33 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 9:41:32 am	Powered Earth Continuity	<0.03 Ohms		Pass
7/1/21, 9:41:38 am	Polarity	OK		Pass
7/1/21, 9:41:49 am	RCD Test	38ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 1:43:58 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 1:44:36 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 1:44:50 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 9:43:40 am	Powered Earth Continuity	<0.03 Ohms		Pass
7/1/21, 9:43:44 am	Polarity	OK		Pass
7/1/21, 9:43:49 am	RCD Test	27ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 1:45:18 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 1:45:30 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 1:45:42 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
7/1/21, 9:44:38 am	Powered Earth Continuity	0.05 Ohms		Pass
7/1/21, 9:44:44 am	Polarity	OK		Pass
7/1/21, 9:44:50 am	RCD Test	28ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 1:46:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 1:46:18 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 1:46:40 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 9:49:17 am	Powered Earth Continuity	<0.03 Ohms		Pass
7/1/21, 9:49:21 am	Polarity	OK		Pass
7/1/21, 9:49:26 am	RCD Test	25ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 1:46:58 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 1:47:08 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 1:47:21 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 9:53:05 am	Powered Earth Continuity	0.33 Ohms		Pass
7/1/21, 9:53:07 am	Polarity	OK		Pass
7/1/21, 9:53:12 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/1/21, 1:47:42 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/1/21, 1:47:53 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/1/21, 1:48:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 9:56:15 am	Powered Earth Continuity	0.04 Ohms		Pass
7/1/21, 9:56:17 am	Polarity	OK		Pass
7/1/21, 9:56:21 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 10**Hotplate**

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 10:25:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 10:25:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 10:26:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 10:36:36 am	Powered Earth Continuity	0.04 Ohms		Pass
7/1/21, 10:36:39 am	Polarity	OK		Pass
7/1/21, 10:36:45 am	RCD Test	38ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 10:26:44 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 10:26:56 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 10:27:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 10:37:14 am	Powered Earth Continuity	0.04 Ohms		Pass
7/1/21, 10:37:19 am	Polarity	OK		Pass
7/1/21, 10:37:24 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 10:27:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 10:28:01 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 10:28:14 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
7/1/21, 10:37:48 am	Powered Earth Continuity	0.10 Ohms		Pass
7/1/21, 10:37:52 am	Polarity	OK		Pass
7/1/21, 10:38:16 am	RCD Test	38ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 10:29:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 10:29:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 10:30:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 10:40:23 am	Powered Earth Continuity	0.28 Ohms		Pass
7/1/21, 10:40:25 am	Polarity	OK		Pass
7/1/21, 10:40:30 am	RCD Test	38ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 10:30:37 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 10:30:49 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 10:31:11 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 10:43:11 am	Powered Earth Continuity	0.14 Ohms		Pass
7/1/21, 10:43:13 am	Polarity	OK		Pass
7/1/21, 10:43:18 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 10:31:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 10:32:06 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 10:32:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 10:48:31 am	Powered Earth Continuity	0.10 Ohms		Pass
7/1/21, 10:48:33 am	Polarity	OK		Pass
7/1/21, 10:48:39 am	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 11

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:01:41 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:02:16 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:02:38 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 12:17:57 pm	Powered Earth Continuity	0.17 Ohms		Pass
7/1/21, 12:18:07 pm	Polarity	OK		Pass
7/1/21, 12:18:35 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:04:05 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:04:19 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:04:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 12:19:05 pm	Powered Earth Continuity	0.16 Ohms		Pass
7/1/21, 12:19:08 pm	Polarity	OK		Pass
7/1/21, 12:19:14 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:05:03 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:05:16 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:05:28 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
7/1/21, 12:19:36 pm	Powered Earth Continuity	0.11 Ohms		Pass
7/1/21, 12:19:42 pm	Polarity	OK		Pass
7/1/21, 12:19:55 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:05:54 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:06:05 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:06:25 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 12:21:47 pm	Polarity	OK		Pass
7/1/21, 12:22:02 pm	Powered Earth Continuity	0.32 Ohms		Pass
7/1/21, 12:22:11 pm	RCD Test	39ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:06:48 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:07:01 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:07:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 12:25:56 pm	Powered Earth Continuity	0.45 Ohms		Pass
7/1/21, 12:25:58 pm	Polarity	OK		Pass
7/1/21, 12:26:03 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:07:41 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:07:54 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:08:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 12:28:43 pm	Powered Earth Continuity	0.08 Ohms		Pass
7/1/21, 12:28:45 pm	Polarity	OK		Pass
7/1/21, 12:28:50 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 12**Hotplate**

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:53:32 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:53:41 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:53:56 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 1:06:32 pm	Powered Earth Continuity	0.07 Ohms		Pass
7/1/21, 1:06:41 pm	Polarity	OK		Pass
7/1/21, 1:06:47 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:55:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:55:36 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:55:49 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 1:07:43 pm	Powered Earth Continuity	0.11 Ohms		Pass
7/1/21, 1:07:47 pm	Polarity	OK		Pass
7/1/21, 1:08:04 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:56:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:56:35 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:56:46 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
7/1/21, 1:08:29 pm	Powered Earth Continuity	0.08 Ohms		Pass
7/1/21, 1:08:32 pm	Polarity	OK		Pass
7/1/21, 1:08:40 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:57:20 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:57:34 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:57:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 1:13:45 pm	Powered Earth Continuity	0.13 Ohms		Pass
7/1/21, 1:13:47 pm	Polarity	OK		Pass
7/1/21, 1:13:52 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:58:15 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:58:28 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:58:43 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 1:14:59 pm	Powered Earth Continuity	0.05 Ohms		Pass
7/1/21, 1:15:01 pm	Polarity	OK		Pass
7/1/21, 1:15:09 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
7/1/21, 12:59:24 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
7/1/21, 12:59:37 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
7/1/21, 12:59:50 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
7/1/21, 1:34:25 pm	Powered Earth Continuity	0.19 Ohms		Pass
7/1/21, 1:34:27 pm	Polarity	OK		Pass
7/1/21, 1:35:22 pm	RCD Test	38ms at 30mA (90 degrees)		Pass

Unit 13

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:19:02 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 7:19:28 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 7:20:15 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 7:47:25 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 7:47:32 am	Polarity	OK		Pass
28/1/21, 7:48:05 am	RCD Test	30ms at 30mA (0 degrees)		Pass
28/1/21, 7:50:00 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Aircon

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:21:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 7:22:39 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 7:23:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 7:50:33 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 7:50:40 am	Polarity	OK		Pass
28/1/21, 7:50:56 am	RCD Test	30ms at 30mA (0 degrees)		Pass
28/1/21, 7:51:12 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:23:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 7:24:05 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 7:24:27 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
28/1/21, 7:51:54 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 7:52:04 am	Polarity	OK		Pass
28/1/21, 7:52:34 am	RCD Test	30ms at 30mA (0 degrees)		Pass
28/1/21, 7:52:49 am	RCD Test	34ms at 30mA (180 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:25:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 7:26:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 7:27:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass

Unit 13, P1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:54:32 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 7:54:37 am	Polarity	OK		Pass
28/1/21, 7:54:48 am	RCD Test	30ms at 30mA (0 degrees)		Pass
28/1/21, 7:55:07 am	RCD Test	34ms at 30mA (180 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:27:54 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 7:28:13 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 7:29:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 7:58:38 am	Powered Earth Continuity	0.30 Ohms		Pass
28/1/21, 7:58:45 am	Polarity	OK		Pass
28/1/21, 7:59:03 am	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 7:59:16 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:31:33 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 7:31:58 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 7:32:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 8:11:58 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 8:12:03 am	Polarity	OK		Pass
28/1/21, 8:12:14 am	RCD Test	29ms at 30mA (0 degrees)		Pass
28/1/21, 8:12:26 am	RCD Test	33ms at 30mA (180 degrees)		Pass

P3 Blinds

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 7:30:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 7:30:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 7:30:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 8:09:14 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 8:09:23 am	Polarity	OK		Pass
28/1/21, 8:09:33 am	RCD Test	30ms at 30mA (0 degrees)		Pass
28/1/21, 8:09:56 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 14

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 8:44:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 8:44:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 8:45:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 8:58:40 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 8:58:46 am	Polarity	OK		Pass
28/1/21, 8:59:06 am	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 8:59:32 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/c

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 8:45:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 8:46:31 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 8:47:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 9:06:33 am	Powered Earth Continuity	0.05 Ohms		Pass

Unit 14, A/c (cont.)

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 9:06:43 am	Polarity	OK		Pass
28/1/21, 9:07:34 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 8:47:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 8:47:42 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 8:48:06 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
28/1/21, 9:12:18 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 9:12:23 am	Polarity	OK		Pass
28/1/21, 9:12:43 am	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 12:57:02 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 8:48:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 8:49:13 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 8:50:12 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 9:14:17 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 9:14:24 am	Polarity	OK		Pass
28/1/21, 9:19:23 am	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 9:19:40 am	RCD Test	34ms at 30mA (180 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 8:50:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 8:51:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 8:51:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 9:21:51 am	Powered Earth Continuity	0.26 Ohms		Pass
28/1/21, 9:21:56 am	Polarity	OK		Pass
28/1/21, 9:22:07 am	RCD Test	23ms at 30mA (0 degrees)		Pass
28/1/21, 9:22:26 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 8:52:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 8:52:28 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 8:52:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 9:25:58 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 9:26:32 am	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 9:26:59 am	RCD Test	34ms at 30mA (180 degrees)		Pass
28/1/21, 12:57:56 pm	Polarity	OK		Pass

Unit 15

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 9:57:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 9:58:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 9:58:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 10:14:59 am	Powered Earth Continuity	<0.03 Ohms		Fail
28/1/21, 10:15:55 am	Polarity	OK		Pass
28/1/21, 10:17:46 am	RCD Test	24ms at 30mA (0 degrees)		Pass

Unit 15, Hot Plate (cont.)

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 10:18:33 am	RCD Test	34ms at 30mA (180 degrees)		Pass
A/C				
Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 9:59:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 9:59:14 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 9:59:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 10:46:53 am	Powered Earth Continuity	0.06 Ohms		Pass
28/1/21, 10:46:59 am	Polarity	OK		Pass
28/1/21, 10:47:21 am	RCD Test	33ms at 30mA (180 degrees)		Pass
28/1/21, 10:47:49 am	RCD Test	28ms at 30mA (0 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 9:59:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 9:59:58 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 10:00:13 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
28/1/21, 10:19:18 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 10:23:26 am	Polarity	OK		Pass
28/1/21, 10:23:41 am	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 12:55:44 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 10:00:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 10:00:56 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 10:01:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 10:25:23 am	Powered Earth Continuity	0.09 Ohms		Pass
28/1/21, 10:25:26 am	Polarity	OK		Pass
28/1/21, 10:25:34 am	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 10:26:15 am	RCD Test	34ms at 30mA (180 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 10:01:29 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 10:01:42 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 10:01:56 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 10:33:10 am	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 10:33:15 am	Polarity	OK		Pass
28/1/21, 10:33:25 am	RCD Test	23ms at 30mA (0 degrees)		Pass
28/1/21, 10:33:39 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 10:02:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 10:02:31 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 10:02:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 10:35:58 am	Powered Earth Continuity	0.07 Ohms		Pass
28/1/21, 10:36:02 am	Polarity	OK		Pass
28/1/21, 10:36:11 am	RCD Test	29ms at 30mA (0 degrees)		Pass
28/1/21, 10:37:16 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 16

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 12:06:55 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 12:07:24 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 12:08:33 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 12:30:14 pm	Powered Earth Continuity	0.07 Ohms		Fail
28/1/21, 12:30:18 pm	Polarity	OK		Pass
28/1/21, 12:30:28 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
28/1/21, 12:30:40 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 12:09:27 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 12:09:44 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 12:10:08 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 12:50:07 pm	Powered Earth Continuity	0.20 Ohms		Fail
28/1/21, 12:50:11 pm	Polarity	OK		Pass
28/1/21, 12:50:27 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
28/1/21, 12:50:51 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 12:11:16 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 12:11:47 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 12:13:25 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 12:31:07 pm	Powered Earth Continuity	0.07 Ohms		Fail
28/1/21, 12:31:11 pm	Polarity	OK		Pass
28/1/21, 12:31:24 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
28/1/21, 12:31:39 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 12:14:11 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 12:15:44 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 12:17:53 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 12:32:31 pm	Powered Earth Continuity	0.27 Ohms		Pass
28/1/21, 12:32:36 pm	Polarity	OK		Pass
28/1/21, 12:32:46 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
28/1/21, 12:33:20 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 12:18:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 12:18:47 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 12:19:19 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 12:36:35 pm	Powered Earth Continuity	0.26 Ohms		Fail
28/1/21, 12:36:41 pm	Polarity	OK		Pass
28/1/21, 12:36:54 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
28/1/21, 12:37:09 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 12:20:04 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 12:20:34 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 12:20:50 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 12:41:42 pm	Powered Earth Continuity	0.07 Ohms		Pass
28/1/21, 12:41:46 pm	Polarity	OK		Pass
28/1/21, 12:42:09 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
28/1/21, 12:42:24 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 17

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 1:23:44 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 1:24:05 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 1:24:58 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 1:42:00 pm	Powered Earth Continuity	0.07 Ohms		Fail
28/1/21, 1:42:05 pm	Polarity	OK		Pass
28/1/21, 1:42:16 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 1:42:35 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 1:25:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 1:25:55 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 1:26:21 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 2:12:40 pm	Powered Earth Continuity	0.04 Ohms		Pass
28/1/21, 2:12:43 pm	Polarity	OK		Pass
28/1/21, 2:12:56 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
28/1/21, 2:13:16 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 1:27:05 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 1:27:22 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 1:27:52 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 1:43:07 pm	Powered Earth Continuity	<0.03 Ohms		Fail
28/1/21, 1:43:10 pm	Polarity	OK		Pass
28/1/21, 1:43:28 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 1:43:44 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P1

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 1:28:58 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 1:29:25 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 1:29:42 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 1:45:33 pm	Powered Earth Continuity	0.06 Ohms		Fail
28/1/21, 1:45:37 pm	Polarity	OK		Pass
28/1/21, 1:45:46 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 1:46:15 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

P2

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 1:30:16 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 1:30:55 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 1:31:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 2:08:03 pm	Powered Earth Continuity	<0.03 Ohms		Pass
28/1/21, 2:08:05 pm	Polarity	OK		Pass
28/1/21, 2:08:15 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
28/1/21, 2:08:30 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
28/1/21, 1:31:51 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
28/1/21, 1:32:06 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
28/1/21, 1:32:28 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
28/1/21, 1:57:00 pm	Powered Earth Continuity	0.15 Ohms		Pass
28/1/21, 1:57:05 pm	Polarity	OK		Pass
28/1/21, 1:57:14 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
28/1/21, 1:57:42 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 18**Hot Plate**

Test Date and Time	Test	Measurement	Notes	Result
3/3/21, 12:45:38 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/3/21, 12:45:50 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/3/21, 12:46:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/3/21, 12:59:18 pm	Powered Earth Continuity	0.16 Ohms		Pass
3/3/21, 12:59:30 pm	Polarity	OK		Pass
3/3/21, 12:59:41 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
3/3/21, 12:59:56 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
3/3/21, 12:46:28 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/3/21, 12:46:42 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/3/21, 12:46:56 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 6:38:50 am	Powered Earth Continuity	0.20 Ohms		Pass
4/3/21, 6:38:53 am	Polarity	OK		Pass
4/3/21, 6:39:02 am	RCD Test	23ms at 30mA (0 degrees)		Pass
4/3/21, 6:40:42 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
3/3/21, 12:47:26 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/3/21, 12:47:39 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/3/21, 12:47:55 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
3/3/21, 1:00:28 pm	Powered Earth Continuity	0.18 Ohms		Pass
3/3/21, 1:00:59 pm	Polarity	OK		Pass
3/3/21, 1:01:16 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
3/3/21, 1:03:21 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
3/21, 12:48:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 12:48:33 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 12:48:45 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/21, 1:06:19 pm	Powered Earth Continuity	0.38 Ohms		Pass
3/21, 1:06:22 pm	Polarity	OK		Pass
3/21, 1:06:31 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
3/21, 1:07:05 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
3/21, 12:49:11 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 12:49:22 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 12:49:39 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/21, 1:04:18 pm	Powered Earth Continuity	0.21 Ohms		Pass
3/21, 1:04:22 pm	Polarity	OK		Pass
3/21, 1:04:43 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
3/21, 1:05:11 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
3/21, 12:50:09 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
3/21, 12:50:25 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
3/21, 12:50:35 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/21, 1:13:49 pm	Powered Earth Continuity	0.16 Ohms		Pass
3/21, 1:13:51 pm	Polarity	OK		Pass
3/21, 1:14:27 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
3/21, 1:14:54 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 19

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 6:59:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 6:59:34 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 6:59:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 7:29:21 am	Powered Earth Continuity	0.06 Ohms		Pass
4/3/21, 7:29:33 am	Polarity	OK		Pass
4/3/21, 7:30:11 am	RCD Test	29ms at 30mA (0 degrees)		Pass
4/3/21, 7:30:22 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 7:02:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 7:02:29 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 7:02:47 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 7:22:38 am	Powered Earth Continuity	0.24 Ohms		Pass
4/3/21, 7:22:44 am	Polarity	OK		Pass
4/3/21, 7:22:54 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 7:25:03 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 7:03:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 7:03:28 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 7:03:43 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
4/3/21, 7:30:53 am	Powered Earth Continuity	0.06 Ohms		Pass
4/3/21, 7:31:00 am	Polarity	OK		Pass
4/3/21, 7:31:07 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 7:31:48 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 7:04:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 7:04:37 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 7:05:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 7:35:16 am	Powered Earth Continuity	0.25 Ohms		Pass
4/3/21, 7:35:18 am	Polarity	OK		Pass
4/3/21, 7:35:46 am	RCD Test	29ms at 30mA (0 degrees)		Pass
4/3/21, 7:36:16 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 7:05:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 7:05:39 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 7:05:54 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 7:39:35 am	Powered Earth Continuity	0.15 Ohms		Pass
4/3/21, 7:39:37 am	Polarity	OK		Pass
4/3/21, 7:39:44 am	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 7:40:12 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 7:06:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 7:06:34 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 7:06:44 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 7:41:25 am	Powered Earth Continuity	0.16 Ohms		Pass
4/3/21, 7:41:28 am	Polarity	OK		Pass
4/3/21, 7:41:34 am	RCD Test	23ms at 30mA (0 degrees)		Pass
4/3/21, 7:42:03 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 20

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 8:40:47 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 8:41:04 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 8:41:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 8:57:30 am	Powered Earth Continuity	0.14 Ohms		Pass
4/3/21, 8:57:34 am	Polarity	OK		Pass
4/3/21, 8:58:01 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 8:58:17 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 8:41:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 8:41:52 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 8:42:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 8:52:21 am	Powered Earth Continuity	0.21 Ohms		Pass
4/3/21, 8:52:24 am	Polarity	OK		Pass
4/3/21, 8:53:23 am	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 8:54:06 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 8:42:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 8:42:53 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 8:43:19 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
4/3/21, 8:58:44 am	Powered Earth Continuity	0.10 Ohms		Pass
4/3/21, 8:58:47 am	Polarity	OK		Pass
4/3/21, 8:59:04 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 8:59:31 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 8:43:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 8:44:09 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 8:44:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 9:03:47 am	Powered Earth Continuity	0.36 Ohms		Pass
4/3/21, 9:03:52 am	Polarity	OK		Pass
4/3/21, 9:04:00 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 9:04:32 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 8:44:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 8:45:09 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 8:45:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 9:08:04 am	Powered Earth Continuity	0.21 Ohms		Pass
4/3/21, 9:08:07 am	Polarity	OK		Pass
4/3/21, 9:08:13 am	RCD Test	23ms at 30mA (0 degrees)		Pass
4/3/21, 9:08:43 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 8:45:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 8:46:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 8:46:19 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 9:11:09 am	Powered Earth Continuity	0.24 Ohms		Pass
4/3/21, 9:11:11 am	Polarity	OK		Pass
4/3/21, 9:11:17 am	RCD Test	23ms at 30mA (0 degrees)		Pass
4/3/21, 9:12:28 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 21

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 9:59:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 9:59:13 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 9:59:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 10:12:27 am	Powered Earth Continuity	0.11 Ohms		Pass
4/3/21, 10:12:31 am	Polarity	OK		Pass
4/3/21, 10:12:44 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 10:13:03 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 10:00:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 10:00:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 10:00:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 10:08:34 am	Powered Earth Continuity	0.27 Ohms		Pass
4/3/21, 10:08:37 am	Polarity	OK		Pass
4/3/21, 10:08:44 am	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 10:09:47 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 10:01:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 10:01:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 10:01:31 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
4/3/21, 10:13:29 am	Powered Earth Continuity	0.11 Ohms		Pass
4/3/21, 10:13:34 am	Polarity	OK		Pass
4/3/21, 10:14:11 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 10:14:29 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 10:01:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 10:02:06 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 10:02:15 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 10:16:15 am	Powered Earth Continuity	0.37 Ohms		Pass
4/3/21, 10:16:17 am	Polarity	OK		Pass
4/3/21, 10:16:24 am	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 10:16:54 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 10:02:33 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 10:02:44 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 10:02:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 10:18:59 am	Powered Earth Continuity	0.47 Ohms		Pass
4/3/21, 10:19:01 am	Polarity	OK		Pass
4/3/21, 10:19:08 am	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 10:19:53 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 10:03:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 10:03:29 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 10:03:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 10:21:11 am	Powered Earth Continuity	0.13 Ohms		Pass
4/3/21, 10:21:13 am	Polarity	OK		Pass
4/3/21, 10:21:19 am	RCD Test	23ms at 30mA (0 degrees)		Pass
4/3/21, 10:21:41 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 22

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 11:46:16 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 11:46:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 11:47:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 12:18:25 pm	Powered Earth Continuity	<0.03 Ohms		Pass
4/3/21, 12:18:32 pm	Polarity	OK		Pass
4/3/21, 12:19:10 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 12:19:28 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 11:47:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 11:47:38 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 11:48:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 12:14:55 pm	Powered Earth Continuity	0.20 Ohms		Pass
4/3/21, 12:14:57 pm	Polarity	OK		Pass
4/3/21, 12:15:04 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 12:16:15 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 11:48:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 11:49:00 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 11:49:13 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
4/3/21, 12:20:23 pm	Powered Earth Continuity	0.07 Ohms		Pass
4/3/21, 12:20:28 pm	Polarity	OK		Pass
4/3/21, 12:20:47 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 12:21:21 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 11:49:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 11:49:42 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 11:49:54 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 12:23:29 pm	Powered Earth Continuity	0.15 Ohms		Pass
4/3/21, 12:23:35 pm	Polarity	OK		Pass
4/3/21, 12:23:41 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 12:24:03 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 11:50:51 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 11:51:03 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 11:51:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 12:26:42 pm	Powered Earth Continuity	0.08 Ohms		Pass
4/3/21, 12:26:44 pm	Polarity	OK		Pass
4/3/21, 12:26:51 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
4/3/21, 12:27:19 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 11:51:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 11:51:56 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 11:52:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 12:28:40 pm	Powered Earth Continuity	0.10 Ohms		Pass
4/3/21, 12:28:42 pm	Polarity	OK		Pass
4/3/21, 12:28:48 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 12:29:11 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 23

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 1:03:46 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 1:03:59 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 1:04:13 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
4/3/21, 1:29:15 pm	Powered Earth Continuity	<0.03 Ohms		Pass
4/3/21, 1:29:19 pm	Polarity	OK		Pass
4/3/21, 1:29:29 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 1:29:58 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 1:04:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 1:04:51 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 1:05:05 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 1:25:34 pm	Powered Earth Continuity	0.13 Ohms		Pass
4/3/21, 1:25:35 pm	Polarity	OK		Pass
4/3/21, 1:25:43 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
4/3/21, 1:27:15 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 1:05:28 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 1:05:41 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 1:05:52 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
4/3/21, 1:30:19 pm	Powered Earth Continuity	<0.03 Ohms		Pass
4/3/21, 1:30:24 pm	Polarity	OK		Pass
4/3/21, 1:30:50 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 1:31:00 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 1:06:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 1:06:33 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 1:06:44 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 1:32:17 pm	Powered Earth Continuity	0.17 Ohms		Pass
4/3/21, 1:32:19 pm	Polarity	OK		Pass
4/3/21, 1:32:26 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
4/3/21, 1:32:51 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 1:07:07 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 1:07:19 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 1:07:31 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 1:35:06 pm	Powered Earth Continuity	0.33 Ohms		Pass
4/3/21, 1:35:08 pm	Polarity	OK		Pass
4/3/21, 1:35:14 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 1:35:42 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 1:07:56 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 1:08:09 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 1:08:19 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
4/3/21, 1:38:01 pm	Powered Earth Continuity	0.08 Ohms		Pass
4/3/21, 1:38:03 pm	Polarity	OK		Pass
4/3/21, 1:38:10 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
4/3/21, 1:38:32 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 24

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 2:07:14 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 2:07:25 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 2:07:43 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 6:40:07 am	Powered Earth Continuity	0.18 Ohms		Pass
5/3/21, 6:40:10 am	Polarity	OK		Pass
5/3/21, 6:40:18 am	RCD Test	28ms at 30mA (0 degrees)		Pass
5/3/21, 6:41:21 am	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 2:08:12 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 2:08:24 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 2:08:38 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 6:44:04 am	Powered Earth Continuity	0.20 Ohms		Pass
5/3/21, 6:44:06 am	Polarity	OK		Pass
5/3/21, 6:44:51 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 6:45:18 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven				
Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 2:08:55 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 2:09:06 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 2:09:18 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/3/21, 6:46:10 am	Powered Earth Continuity	0.05 Ohms		Pass
5/3/21, 6:46:25 am	Polarity	OK		Pass
5/3/21, 6:46:42 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 6:46:53 am	RCD Test	34ms at 30mA (180 degrees)		Pass
Power 1				
Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 2:09:39 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 2:09:50 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 2:09:59 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 6:49:09 am	Powered Earth Continuity	0.16 Ohms		Pass
5/3/21, 6:49:11 am	Polarity	OK		Pass
5/3/21, 6:49:17 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 6:49:55 am	RCD Test	34ms at 30mA (180 degrees)		Pass
Power 2				
Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 2:10:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 2:10:28 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 2:10:43 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 6:54:11 am	Powered Earth Continuity	0.12 Ohms		Pass
5/3/21, 6:54:13 am	Polarity	OK		Pass
5/3/21, 6:54:20 am	RCD Test	23ms at 30mA (0 degrees)		Pass
5/3/21, 6:54:47 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Lights				
Test Date and Time	Test	Measurement	Notes	Result
4/3/21, 2:11:01 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
4/3/21, 2:11:16 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
4/3/21, 2:11:29 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 6:55:46 am	Powered Earth Continuity	0.09 Ohms		Pass
5/3/21, 6:55:49 am	Polarity	OK		Pass
5/3/21, 6:55:55 am	RCD Test	23ms at 30mA (0 degrees)		Pass
5/3/21, 6:56:22 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Unit 25				
Hot Plate				
Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 7:39:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 7:40:00 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 7:40:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 7:53:47 am	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 7:53:53 am	Polarity	OK		Pass
5/3/21, 7:54:03 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 7:54:26 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 7:40:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 7:41:00 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 7:41:15 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 7:49:51 am	Powered Earth Continuity	0.16 Ohms		Pass
5/3/21, 7:49:55 am	Polarity	OK		Pass
5/3/21, 7:50:02 am	RCD Test	29ms at 30mA (0 degrees)		Pass
5/3/21, 7:50:48 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 7:41:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 7:41:46 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 7:41:58 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/3/21, 7:55:08 am	Powered Earth Continuity	0.04 Ohms		Pass
5/3/21, 7:55:11 am	Polarity	OK		Pass
5/3/21, 7:55:21 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 7:55:37 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 7:42:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 7:42:36 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 7:42:46 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 7:57:40 am	Powered Earth Continuity	0.21 Ohms		Pass
5/3/21, 7:57:43 am	Polarity	OK		Pass
5/3/21, 7:57:49 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 7:58:20 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 7:43:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 7:43:19 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 7:43:33 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 8:01:38 am	Powered Earth Continuity	0.34 Ohms		Pass
5/3/21, 8:01:40 am	Polarity	OK		Pass
5/3/21, 8:01:46 am	RCD Test	28ms at 30mA (0 degrees)		Pass
5/3/21, 8:02:22 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 7:43:54 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 7:44:06 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 7:44:16 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 8:04:43 am	Powered Earth Continuity	0.15 Ohms		Pass
5/3/21, 8:04:45 am	Polarity	OK		Pass
5/3/21, 8:04:50 am	RCD Test	29ms at 30mA (0 degrees)		Pass
5/3/21, 8:05:36 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 26

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:43:31 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:43:42 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:43:54 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/21, 8:57:19 am	Powered Earth Continuity	0.06 Ohms		Pass
5/21, 8:57:28 am	Polarity	OK		Pass
5/21, 8:59:41 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 8:59:58 am	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:44:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:44:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:44:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:51:50 am	Powered Earth Continuity	0.24 Ohms		Pass
5/21, 8:51:52 am	Polarity	OK		Pass
5/21, 8:51:58 am	RCD Test	23ms at 30mA (0 degrees)		Pass
5/21, 8:53:06 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:45:04 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:45:16 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:45:32 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/21, 9:00:22 am	Powered Earth Continuity	<0.03 Ohms		Pass
5/21, 9:00:24 am	Polarity	OK		Pass
5/21, 9:00:31 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 9:00:53 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:45:54 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:46:05 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:46:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 9:02:33 am	Powered Earth Continuity	<0.03 Ohms		Pass
5/21, 9:02:35 am	Polarity	OK		Pass
5/21, 9:02:42 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 9:03:07 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:46:36 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:46:49 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:47:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 9:07:12 am	Powered Earth Continuity	0.17 Ohms		Pass
5/21, 9:07:14 am	Polarity	OK		Pass
5/21, 9:07:20 am	RCD Test	23ms at 30mA (0 degrees)		Pass
5/21, 9:07:48 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:47:29 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:47:41 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:47:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 9:09:07 am	Powered Earth Continuity	0.10 Ohms		Pass
5/21, 9:09:09 am	Polarity	OK		Pass
5/21, 9:09:57 am	RCD Test	23ms at 30mA (0 degrees)		Pass
5/21, 9:10:23 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 27

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:44:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:44:33 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:44:47 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:24:15 am	Powered Earth Continuity	<0.03 Ohms		Pass
5/21, 10:24:20 am	Polarity	OK		Pass
5/21, 10:24:31 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 10:24:47 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:45:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:45:19 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:45:37 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:20:43 am	Powered Earth Continuity	0.10 Ohms		Pass
5/21, 10:20:45 am	Polarity	OK		Pass
5/21, 10:20:51 am	RCD Test	28ms at 30mA (0 degrees)		Pass
5/21, 10:22:18 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:46:04 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:46:15 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:46:32 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/21, 10:25:28 am	Powered Earth Continuity	<0.03 Ohms		Pass
5/21, 10:25:30 am	Polarity	OK		Pass
5/21, 10:25:36 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 10:25:50 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:46:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:47:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:47:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:28:04 am	Powered Earth Continuity	0.12 Ohms		Pass
5/21, 10:28:06 am	Polarity	OK		Pass
5/21, 10:28:12 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 10:28:47 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 9:47:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 9:48:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 9:48:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 10:31:47 am	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 10:31:49 am	Polarity	OK		Pass
5/3/21, 10:31:57 am	RCD Test	28ms at 30mA (0 degrees)		Pass
5/3/21, 10:32:32 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 10:17:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 10:17:27 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 10:17:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 10:36:03 am	Powered Earth Continuity	0.06 Ohms		Pass
5/3/21, 10:36:05 am	Polarity	OK		Pass
5/3/21, 10:36:11 am	RCD Test	30ms at 30mA (0 degrees)		Pass
5/3/21, 10:36:30 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 28

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 11:51:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 11:51:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 11:52:15 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 12:13:48 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 12:13:52 pm	Polarity	OK		Pass
5/3/21, 12:13:59 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 12:14:26 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 11:52:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 11:52:47 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 11:53:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 12:09:29 pm	Powered Earth Continuity	0.13 Ohms		Pass
5/3/21, 12:09:58 pm	Polarity	OK		Pass
5/3/21, 12:10:04 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
5/3/21, 12:12:10 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 11:53:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 11:53:27 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 11:53:39 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/3/21, 12:14:53 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 12:14:55 pm	Polarity	OK		Pass
5/3/21, 12:15:00 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 12:15:11 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 11:54:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 11:54:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 11:54:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 12:17:05 pm	Powered Earth Continuity	0.16 Ohms		Pass
5/3/21, 12:17:07 pm	Polarity	OK		Pass
5/3/21, 12:17:14 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 12:17:34 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 11:55:16 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 11:55:28 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 11:55:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 12:20:09 pm	Powered Earth Continuity	0.31 Ohms		Pass
5/3/21, 12:20:11 pm	Polarity	OK		Pass
5/3/21, 12:20:16 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
5/3/21, 12:20:42 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 11:55:57 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 11:56:08 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 11:56:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 12:25:53 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 12:25:55 pm	Polarity	OK		Pass
5/3/21, 12:26:43 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
5/3/21, 12:27:19 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 29

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 1:06:04 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 1:06:16 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 1:06:30 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/3/21, 1:20:35 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 1:20:46 pm	Polarity	OK		Pass
5/3/21, 1:21:04 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 1:21:36 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 1:06:53 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 1:07:04 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 1:07:21 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 1:16:00 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 1:16:02 pm	Polarity	OK		Pass
5/3/21, 1:16:08 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
5/3/21, 1:17:28 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven				
Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 1:07:50 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 1:08:20 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 1:08:33 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
5/3/21, 1:22:43 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 1:22:47 pm	Polarity	OK		Pass
5/3/21, 1:22:52 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 1:23:03 pm	RCD Test	34ms at 30mA (180 degrees)		Pass
Power 1				
Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 1:09:03 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 1:09:15 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 1:09:33 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 1:24:32 pm	Powered Earth Continuity	0.06 Ohms		Pass
5/3/21, 1:24:34 pm	Polarity	OK		Pass
5/3/21, 1:24:40 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 1:25:12 pm	RCD Test	34ms at 30mA (180 degrees)		Pass
Power 2				
Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 1:09:53 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 1:10:05 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 1:10:22 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 1:27:24 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 1:27:26 pm	Polarity	OK		Pass
5/3/21, 1:27:35 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/3/21, 1:28:12 pm	RCD Test	33ms at 30mA (180 degrees)		Pass
Lights				
Test Date and Time	Test	Measurement	Notes	Result
5/3/21, 1:11:33 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/3/21, 1:11:47 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/3/21, 1:11:58 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/3/21, 1:30:30 pm	Powered Earth Continuity	<0.03 Ohms		Pass
5/3/21, 1:30:32 pm	Polarity	OK		Pass
5/3/21, 1:30:39 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
5/3/21, 1:31:16 pm	RCD Test	33ms at 30mA (180 degrees)		Pass
Unit 30				
Hot Plate				
Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 7:25:32 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 7:25:44 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 7:26:01 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
8/3/21, 7:44:48 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 7:44:50 am	Polarity	OK		Pass
8/3/21, 7:45:01 am	RCD Test	24ms at 30mA (0 degrees)		Pass
A/C				
Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 7:26:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 7:27:01 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 30, A/C (cont.)

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 7:27:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 7:40:22 am	Powered Earth Continuity	0.08 Ohms		Pass
8/3/21, 7:40:24 am	Polarity	OK		Pass
8/3/21, 7:40:30 am	RCD Test	28ms at 30mA (0 degrees)		Pass
8/3/21, 7:41:20 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 7:28:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 7:28:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 7:28:42 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
8/3/21, 7:46:14 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 7:46:17 am	Polarity	OK		Pass
8/3/21, 7:46:22 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 7:46:32 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 7:29:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 7:29:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 7:29:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 7:48:19 am	Powered Earth Continuity	0.18 Ohms		Pass
8/3/21, 7:48:24 am	Polarity	OK		Pass
8/3/21, 7:48:31 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 7:49:24 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 7:30:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 7:30:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 7:30:33 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 7:52:38 am	Powered Earth Continuity	0.15 Ohms		Pass
8/3/21, 7:52:39 am	Polarity	OK		Pass
8/3/21, 7:52:46 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 7:53:24 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 7:30:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 7:31:12 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 7:31:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 7:55:40 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 7:55:42 am	Polarity	OK		Pass
8/3/21, 7:55:48 am	RCD Test	28ms at 30mA (0 degrees)		Pass
8/3/21, 7:56:19 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 31

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 8:24:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 8:24:49 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 8:25:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass

Unit 31, Hot Plate (cont.)

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 8:36:07 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 8:36:14 am	Polarity	OK		Pass
8/3/21, 8:36:25 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 8:36:46 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 8:25:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 8:25:40 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 8:25:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 8:33:36 am	Powered Earth Continuity	0.15 Ohms		Pass
8/3/21, 8:33:38 am	Polarity	OK		Pass
8/3/21, 8:33:44 am	RCD Test	23ms at 30mA (0 degrees)		Pass
8/3/21, 8:34:54 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 8:26:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 8:26:36 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 8:26:54 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
8/3/21, 8:37:50 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 8:37:52 am	Polarity	OK		Pass
8/3/21, 8:37:59 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 8:38:11 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 8:27:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 8:27:26 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 8:27:49 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 8:40:32 am	Powered Earth Continuity	0.22 Ohms		Pass
8/3/21, 8:40:34 am	Polarity	OK		Pass
8/3/21, 8:40:41 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 8:41:24 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 8:28:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 8:28:20 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 8:28:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 8:44:57 am	Powered Earth Continuity	0.20 Ohms		Pass
8/3/21, 8:44:59 am	Polarity	OK		Pass
8/3/21, 8:45:06 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 8:46:46 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 8:28:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 8:29:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 8:29:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 8:48:25 am	Powered Earth Continuity	0.04 Ohms		Pass
8/3/21, 8:48:27 am	Polarity	OK		Pass
8/3/21, 8:51:28 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 32

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 9:28:29 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 9:28:40 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 9:28:56 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 9:40:56 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 9:40:59 am	Polarity	OK		Pass
8/3/21, 9:41:13 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 9:41:28 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 9:29:15 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 9:29:25 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 9:29:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 9:37:57 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 9:37:59 am	Polarity	OK		Pass
8/3/21, 9:38:06 am	RCD Test	28ms at 30mA (0 degrees)		Pass
8/3/21, 9:39:08 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 9:30:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 9:30:14 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 9:30:26 am	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
8/3/21, 9:42:15 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 9:42:17 am	Polarity	OK		Pass
8/3/21, 9:42:23 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 9:42:35 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 9:30:46 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 9:30:57 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 9:31:10 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 9:44:24 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 9:44:26 am	Polarity	OK		Pass
8/3/21, 9:44:32 am	RCD Test	24ms at 30mA (0 degrees)		Pass
8/3/21, 9:44:55 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 9:31:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 9:31:43 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 9:31:56 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 9:47:05 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 9:47:06 am	Polarity	OK		Pass
8/3/21, 9:47:13 am	RCD Test	23ms at 30mA (0 degrees)		Pass
8/3/21, 9:47:43 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
8/3/21, 9:32:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
8/3/21, 9:32:30 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
8/3/21, 9:32:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
8/3/21, 9:49:13 am	Powered Earth Continuity	<0.03 Ohms		Pass
8/3/21, 9:49:15 am	Polarity	OK		Pass
8/3/21, 9:49:20 am	RCD Test	29ms at 30mA (0 degrees)		Pass
8/3/21, 9:49:40 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 33

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 12:22:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 12:22:59 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 12:23:14 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 12:38:49 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 12:38:55 pm	Polarity	OK		Pass
10/3/21, 12:39:31 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
10/3/21, 12:39:50 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 12:23:34 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 12:23:45 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 12:24:00 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 12:35:35 pm	Powered Earth Continuity	0.06 Ohms		Pass
10/3/21, 12:35:37 pm	Polarity	OK		Pass
10/3/21, 12:35:43 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
10/3/21, 12:36:40 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 12:24:22 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 12:24:33 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 12:25:03 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
10/3/21, 12:40:38 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 12:40:40 pm	Polarity	OK		Pass
10/3/21, 12:40:46 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
10/3/21, 12:41:02 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 12:25:53 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 12:26:05 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 12:26:18 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 12:42:27 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 12:42:29 pm	Polarity	OK		Pass
10/3/21, 12:42:35 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
10/3/21, 12:42:55 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 12:26:41 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 12:26:52 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 12:27:42 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 12:45:40 pm	Powered Earth Continuity	0.06 Ohms		Pass
10/3/21, 12:45:42 pm	Polarity	OK		Pass
10/3/21, 12:45:49 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
10/3/21, 12:46:35 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 12:28:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 12:28:18 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 12:28:30 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 12:48:59 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 12:49:01 pm	Polarity	OK		Pass
10/3/21, 12:49:07 pm	RCD Test	23ms at 30mA (0 degrees)		Pass

Unit 34

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 1:27:55 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 1:28:06 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 1:28:22 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 1:43:07 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 1:43:09 pm	Polarity	OK		Pass
10/3/21, 1:43:16 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
10/3/21, 1:43:48 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 1:28:43 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 1:28:54 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 1:29:12 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 1:39:51 pm	Powered Earth Continuity	0.04 Ohms		Pass
10/3/21, 1:40:11 pm	Polarity	OK		Pass
10/3/21, 1:40:19 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
10/3/21, 1:41:27 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 1:29:36 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 1:29:48 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 1:30:10 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
10/3/21, 1:44:46 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 1:44:48 pm	Polarity	OK		Pass
10/3/21, 1:45:05 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
10/3/21, 1:45:47 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 1:30:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 1:30:49 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 34, Power 1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 1:31:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 1:48:12 pm	Powered Earth Continuity	0.06 Ohms		Pass
10/3/21, 1:48:14 pm	Polarity	OK		Pass
10/3/21, 1:48:21 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
10/3/21, 1:48:51 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 1:32:03 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 1:32:14 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 1:32:32 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 1:50:31 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 1:50:33 pm	Polarity	OK		Pass
10/3/21, 1:50:41 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
10/3/21, 1:51:17 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
10/3/21, 1:33:08 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
10/3/21, 1:33:19 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
10/3/21, 1:33:28 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
10/3/21, 1:53:52 pm	Powered Earth Continuity	<0.03 Ohms		Pass
10/3/21, 1:53:55 pm	Polarity	OK		Pass
10/3/21, 1:54:01 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
10/3/21, 1:54:19 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 35

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 12:21:13 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 12:21:24 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 12:21:39 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 12:35:54 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 12:36:38 pm	Polarity	OK		Pass
11/3/21, 12:36:45 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
11/3/21, 12:37:28 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 12:22:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 12:22:16 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 12:22:32 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 12:32:10 pm	Powered Earth Continuity	0.06 Ohms		Pass
11/3/21, 12:32:12 pm	Polarity	OK		Pass
11/3/21, 12:32:18 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
11/3/21, 12:33:12 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 12:22:56 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 12:23:09 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 12:23:21 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass

Unit 35, Oven (cont.)

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 12:38:01 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 12:38:05 pm	Polarity	OK		Pass
11/3/21, 12:38:11 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
11/3/21, 12:38:23 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 12:23:49 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 12:23:59 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 12:24:11 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 12:42:47 pm	Powered Earth Continuity	0.11 Ohms		Pass
11/3/21, 12:43:12 pm	Polarity	OK		Pass
11/3/21, 12:43:32 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
11/3/21, 12:44:23 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 12:24:32 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 12:24:43 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 12:24:58 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 12:46:35 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 12:46:37 pm	Polarity	OK		Pass
11/3/21, 12:48:00 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
11/3/21, 12:48:32 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Light

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 12:25:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 12:25:34 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 12:25:46 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 12:54:28 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 12:54:30 pm	Polarity	OK		Pass
11/3/21, 12:54:37 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
11/3/21, 12:55:05 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 36

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
25/3/21, 12:26:29 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/3/21, 12:26:41 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/3/21, 12:27:01 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/3/21, 1:16:19 pm	Powered Earth Continuity	<0.03 Ohms		Pass
25/3/21, 1:16:21 pm	Polarity	OK		Pass
25/3/21, 1:16:24 pm	Circuit Connections	OK		Pass
25/3/21, 1:16:59 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/3/21, 1:17:10 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
25/3/21, 12:27:19 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/3/21, 12:46:50 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/3/21, 12:47:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass

Unit 36, A/C (cont.)

Test Date and Time	Test	Measurement	Notes	Result
25/3/21, 1:19:25 pm	Powered Earth Continuity	0.16 Ohms		Pass
25/3/21, 1:19:27 pm	Polarity	OK		Pass
25/3/21, 1:19:30 pm	Circuit Connections	OK		Pass
25/3/21, 1:19:37 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/3/21, 1:20:10 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
25/3/21, 12:47:36 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/3/21, 12:47:48 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/3/21, 12:48:01 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
25/3/21, 1:17:32 pm	Powered Earth Continuity	<0.03 Ohms		Pass
25/3/21, 1:17:35 pm	Polarity	OK		Pass
25/3/21, 1:17:37 pm	Circuit Connections	OK		Pass
25/3/21, 1:17:45 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/3/21, 1:18:09 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
25/3/21, 12:48:39 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/3/21, 12:48:54 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/3/21, 12:49:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/3/21, 1:26:08 pm	Powered Earth Continuity	0.25 Ohms		Pass
25/3/21, 1:26:11 pm	Polarity	OK		Pass
25/3/21, 1:26:13 pm	Circuit Connections	OK		Pass
25/3/21, 1:26:21 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/3/21, 1:26:45 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
25/3/21, 12:49:31 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/3/21, 12:49:43 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/3/21, 12:50:01 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/3/21, 1:30:30 pm	Powered Earth Continuity	0.13 Ohms		Pass
25/3/21, 1:30:31 pm	Polarity	OK		Pass
25/3/21, 1:30:33 pm	Circuit Connections	OK		Pass
25/3/21, 1:30:40 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
25/3/21, 1:31:55 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
25/3/21, 12:50:28 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/3/21, 12:50:40 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/3/21, 12:50:52 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/3/21, 2:02:12 pm	Powered Earth Continuity	<0.03 Ohms		Pass
25/3/21, 2:02:14 pm	Polarity	OK		Pass
25/3/21, 2:02:16 pm	Circuit Connections	OK		Pass
25/3/21, 2:02:25 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/3/21, 2:02:38 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 37

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 1:33:20 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 1:33:30 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 1:33:43 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 1:42:36 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 1:42:39 pm	Polarity	OK		Pass
11/3/21, 1:43:17 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
11/3/21, 1:43:39 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 1:34:03 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 1:34:14 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 1:34:28 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 1:44:12 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 1:44:15 pm	Polarity	OK		Pass
11/3/21, 1:44:23 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
11/3/21, 1:44:32 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 1:34:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 1:34:58 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 1:35:08 pm	Insulation Resistance	<0.25 M.Ohms at 500V (A-N)		Pass
11/3/21, 1:44:59 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 1:45:01 pm	Polarity	OK		Pass
11/3/21, 1:45:09 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
11/3/21, 1:45:18 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 1:35:38 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 1:35:49 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 1:36:01 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 1:46:43 pm	Powered Earth Continuity	0.05 Ohms		Pass
11/3/21, 1:46:45 pm	Polarity	OK		Pass
11/3/21, 1:46:51 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
11/3/21, 1:47:14 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 1:36:19 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 1:36:31 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 1:36:44 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 1:51:50 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 1:51:52 pm	Polarity	OK		Pass
11/3/21, 1:52:09 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
11/3/21, 1:52:37 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
11/3/21, 1:37:09 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
11/3/21, 1:37:20 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
11/3/21, 1:37:30 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
11/3/21, 1:39:12 pm	Powered Earth Continuity	<0.03 Ohms		Pass
11/3/21, 1:39:14 pm	Polarity	OK		Pass
11/3/21, 1:39:20 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
11/3/21, 1:40:36 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 38

Stove

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 7:55:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 7:55:46 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 7:56:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 8:16:06 am	Powered Earth Continuity	0.09 Ohms		Pass
14/4/21, 8:16:08 am	Polarity	OK		Pass
14/4/21, 8:16:11 am	Circuit Connections	OK		Pass
14/4/21, 8:16:18 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 8:17:06 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 7:56:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 7:56:43 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 7:57:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 8:11:46 am	Powered Earth Continuity	0.11 Ohms		Pass
14/4/21, 8:11:49 am	Polarity	OK		Pass
14/4/21, 8:11:52 am	Circuit Connections	OK		Pass
14/4/21, 8:11:59 am	RCD Test	28ms at 30mA (0 degrees)		Pass
14/4/21, 8:13:13 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 7:57:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 7:57:38 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 7:57:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 8:17:33 am	Powered Earth Continuity	0.10 Ohms		Pass
14/4/21, 8:17:40 am	Polarity	OK		Pass
14/4/21, 8:17:42 am	Circuit Connections	OK		Pass
14/4/21, 8:18:00 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 8:18:44 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 7:58:20 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 7:58:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 7:58:44 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 8:20:47 am	Powered Earth Continuity	0.17 Ohms		Pass
14/4/21, 8:20:50 am	Polarity	OK		Pass
14/4/21, 8:20:52 am	Circuit Connections	OK		Pass
14/4/21, 8:20:58 am	RCD Test	30ms at 30mA (0 degrees)		Pass

Unit 38, Power 1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 8:23:30 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 7:59:11 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 7:59:23 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 7:59:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 8:26:06 am	Powered Earth Continuity	0.42 Ohms		Pass
14/4/21, 8:26:09 am	Polarity	OK		Pass
14/4/21, 8:26:12 am	Circuit Connections	OK		Pass
14/4/21, 8:26:39 am	RCD Test	24ms at 30mA (0 degrees)		Pass
14/4/21, 8:27:17 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 8:03:19 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 8:03:31 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 8:03:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 8:28:28 am	Powered Earth Continuity	0.12 Ohms		Pass
14/4/21, 8:28:33 am	Polarity	OK		Pass
14/4/21, 8:28:35 am	Circuit Connections	OK		Pass
14/4/21, 8:28:42 am	RCD Test	28ms at 30mA (0 degrees)		Pass
14/4/21, 8:29:01 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 39

Stove

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:01:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:01:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:01:44 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 9:13:55 am	Powered Earth Continuity	0.11 Ohms		Pass
14/4/21, 9:14:06 am	Polarity	OK		Pass
14/4/21, 9:14:11 am	Circuit Connections	OK		Pass
14/4/21, 9:14:35 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 9:14:50 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:02:10 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:02:23 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:02:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 9:09:57 am	Powered Earth Continuity	0.22 Ohms		Pass
14/4/21, 9:09:59 am	Polarity	OK		Pass
14/4/21, 9:10:01 am	Circuit Connections	OK		Pass
14/4/21, 9:10:12 am	RCD Test	23ms at 30mA (0 degrees)		Pass
14/4/21, 9:11:24 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:02:56 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:03:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:03:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass

Unit 39, Oven (cont.)

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:15:23 am	Powered Earth Continuity	0.11 Ohms		Pass
14/4/21, 9:15:25 am	Polarity	OK		Pass
14/4/21, 9:15:28 am	Circuit Connections	OK		Pass
14/4/21, 9:15:38 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 9:15:51 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:03:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:03:54 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:04:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 9:17:38 am	Powered Earth Continuity	0.32 Ohms		Pass
14/4/21, 9:17:40 am	Polarity	OK		Pass
14/4/21, 9:17:43 am	Circuit Connections	OK		Pass
14/4/21, 9:17:49 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 9:18:15 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:04:37 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:04:48 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:05:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 9:21:00 am	Powered Earth Continuity	0.42 Ohms		Pass
14/4/21, 9:21:02 am	Polarity	OK		Pass
14/4/21, 9:21:04 am	Circuit Connections	OK		Pass
14/4/21, 9:21:11 am	RCD Test	29ms at 30mA (0 degrees)		Pass
14/4/21, 9:21:49 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:05:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:05:35 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:05:49 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 9:22:54 am	Powered Earth Continuity	0.15 Ohms		Pass
14/4/21, 9:22:57 am	Polarity	OK		Pass
14/4/21, 9:23:00 am	Circuit Connections	OK		Pass
14/4/21, 9:23:09 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 9:23:50 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 40

Stove

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:50:12 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:50:50 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:51:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 10:04:27 am	Powered Earth Continuity	0.11 Ohms		Pass
14/4/21, 10:04:29 am	Polarity	OK		Pass
14/4/21, 10:04:32 am	Circuit Connections	OK		Pass
14/4/21, 10:04:38 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 10:05:04 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:51:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:51:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:52:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 10:00:40 am	Powered Earth Continuity	0.20 Ohms		Pass
14/4/21, 10:00:54 am	Polarity	OK		Pass
14/4/21, 10:00:56 am	Circuit Connections	OK		Pass
14/4/21, 10:01:03 am	RCD Test	28ms at 30mA (0 degrees)		Pass
14/4/21, 10:02:26 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:52:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:52:47 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:52:57 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 10:05:36 am	Powered Earth Continuity	0.12 Ohms		Pass
14/4/21, 10:05:59 am	Polarity	OK		Pass
14/4/21, 10:06:03 am	Circuit Connections	OK		Pass
14/4/21, 10:06:10 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 10:06:21 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:53:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:53:29 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:53:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 10:09:57 am	Powered Earth Continuity	0.25 Ohms		Pass
14/4/21, 10:10:05 am	Polarity	OK		Pass
14/4/21, 10:10:09 am	Circuit Connections	OK		Pass
14/4/21, 10:10:15 am	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 10:10:43 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:54:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:54:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:54:36 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 10:13:24 am	Powered Earth Continuity	0.25 Ohms		Pass
14/4/21, 10:13:28 am	Polarity	OK		Pass
14/4/21, 10:13:31 am	Circuit Connections	OK		Pass
14/4/21, 10:13:38 am	RCD Test	28ms at 30mA (0 degrees)		Pass
14/4/21, 10:14:16 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 9:54:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 9:55:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 9:55:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 10:15:56 am	Powered Earth Continuity	0.15 Ohms		Pass
14/4/21, 10:15:58 am	Polarity	OK		Pass
14/4/21, 10:15:59 am	Circuit Connections	OK		Pass
14/4/21, 10:16:05 am	RCD Test	29ms at 30mA (0 degrees)		Pass
14/4/21, 10:16:31 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 41

Stove

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 11:48:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 11:48:14 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 11:48:32 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 12:01:03 pm	Powered Earth Continuity	0.22 Ohms		Pass
14/4/21, 12:01:05 pm	Polarity	OK		Pass
14/4/21, 12:01:07 pm	Circuit Connections	OK		Pass
14/4/21, 12:01:13 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
14/4/21, 12:01:24 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 11:49:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 11:49:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 11:49:37 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 11:57:27 am	Powered Earth Continuity	0.37 Ohms		Pass
14/4/21, 11:57:30 am	Polarity	OK		Pass
14/4/21, 11:57:32 am	Circuit Connections	OK		Pass
14/4/21, 11:57:38 am	RCD Test	28ms at 30mA (0 degrees)		Pass
14/4/21, 11:58:41 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 11:50:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 11:50:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 11:50:31 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 12:02:10 pm	Powered Earth Continuity	0.20 Ohms		Pass
14/4/21, 12:02:12 pm	Polarity	OK		Pass
14/4/21, 12:02:16 pm	Circuit Connections	OK		Pass
14/4/21, 12:02:22 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
14/4/21, 12:02:32 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 11:50:52 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 11:51:05 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 11:51:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 12:05:22 pm	Powered Earth Continuity	0.60 Ohms		Pass
14/4/21, 12:05:25 pm	Polarity	OK		Pass
14/4/21, 12:05:27 pm	Circuit Connections	OK		Pass
14/4/21, 12:05:32 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
14/4/21, 12:06:00 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 11:51:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 11:51:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 11:52:11 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 12:09:28 pm	Powered Earth Continuity	0.42 Ohms		Pass
14/4/21, 12:09:32 pm	Polarity	OK		Pass
14/4/21, 12:09:34 pm	Circuit Connections	OK		Pass

Unit 41, Power 2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 12:09:40 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
14/4/21, 12:10:03 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 11:52:47 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 11:52:59 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 11:53:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 12:11:22 pm	Powered Earth Continuity	0.16 Ohms		Pass
14/4/21, 12:11:25 pm	Polarity	OK		Pass
14/4/21, 12:11:27 pm	Circuit Connections	OK		Pass
14/4/21, 12:11:33 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
14/4/21, 12:13:26 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 42

Stove

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 7:12:10 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 7:12:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 7:12:49 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 7:45:11 am	Powered Earth Continuity	0.20 Ohms		Pass
15/4/21, 7:45:16 am	Polarity	OK		Pass
15/4/21, 7:45:18 am	Circuit Connections	OK		Pass
15/4/21, 7:45:25 am	RCD Test	30ms at 30mA (0 degrees)		Pass
15/4/21, 7:45:43 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 7:15:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 7:15:31 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 7:15:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 7:41:15 am	Powered Earth Continuity	0.20 Ohms		Pass
15/4/21, 7:41:17 am	Polarity	OK		Pass
15/4/21, 7:41:20 am	Circuit Connections	OK		Pass
15/4/21, 7:41:26 am	RCD Test	28ms at 30mA (0 degrees)		Pass
15/4/21, 7:42:03 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 7:16:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 7:16:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 7:16:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 7:46:22 am	Powered Earth Continuity	0.18 Ohms		Pass
15/4/21, 7:46:24 am	Polarity	OK		Pass
15/4/21, 7:46:26 am	Circuit Connections	OK		Pass
15/4/21, 7:46:31 am	RCD Test	30ms at 30mA (0 degrees)		Pass
15/4/21, 7:46:41 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 7:16:56 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 7:17:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 42, Power 1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 7:17:19 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 7:48:29 am	Powered Earth Continuity	0.19 Ohms		Pass
15/4/21, 7:48:31 am	Polarity	OK		Pass
15/4/21, 7:48:34 am	Circuit Connections	OK		Pass
15/4/21, 7:48:49 am	RCD Test	30ms at 30mA (0 degrees)		Pass
15/4/21, 7:49:17 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 7:17:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 7:17:52 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 7:18:06 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 7:53:14 am	Powered Earth Continuity	0.26 Ohms		Pass
15/4/21, 7:53:17 am	Polarity	OK		Pass
15/4/21, 7:53:19 am	Circuit Connections	OK		Pass
15/4/21, 7:53:26 am	RCD Test	23ms at 30mA (0 degrees)		Pass
15/4/21, 7:53:55 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 7:18:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 7:18:40 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 7:18:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 7:55:19 am	Powered Earth Continuity	0.23 Ohms		Pass
15/4/21, 7:55:21 am	Polarity	OK		Pass
15/4/21, 7:55:24 am	Circuit Connections	OK		Pass
15/4/21, 7:55:29 am	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 7:55:56 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 43

Stove

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 1:31:30 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 1:31:41 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 1:31:53 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 1:50:09 pm	Powered Earth Continuity	0.16 Ohms		Pass
14/4/21, 1:50:11 pm	Polarity	OK		Pass
14/4/21, 1:50:14 pm	Circuit Connections	OK		Pass
14/4/21, 1:50:24 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 1:50:36 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 1:32:12 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 1:32:23 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 1:32:38 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 1:45:24 pm	Powered Earth Continuity	0.31 Ohms		Pass
14/4/21, 1:45:28 pm	Polarity	OK		Pass
14/4/21, 1:45:30 pm	Circuit Connections	OK		Pass
14/4/21, 1:45:59 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
14/4/21, 1:47:27 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven				
Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 1:32:59 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 1:33:12 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 1:33:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 1:50:59 pm	Powered Earth Continuity	0.15 Ohms		Pass
14/4/21, 1:51:03 pm	Polarity	OK		Pass
14/4/21, 1:51:05 pm	Circuit Connections	OK		Pass
14/4/21, 1:51:35 pm	RCD Test	34ms at 30mA (180 degrees)		Pass
14/4/21, 1:51:50 pm	RCD Test	30ms at 30mA (0 degrees)		Pass

Power 1				
Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 1:33:45 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 1:33:57 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 1:34:13 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 1:53:28 pm	Powered Earth Continuity	0.22 Ohms		Pass
14/4/21, 1:53:30 pm	Polarity	OK		Pass
14/4/21, 1:53:32 pm	Circuit Connections	OK		Pass
14/4/21, 1:53:38 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
14/4/21, 1:53:56 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2				
Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 1:34:33 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 1:34:45 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 1:35:03 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 1:56:50 pm	Powered Earth Continuity	0.45 Ohms		Pass
14/4/21, 1:56:50 pm	Polarity	OK		Pass
14/4/21, 1:57:19 pm	Circuit Connections	OK		Pass
14/4/21, 1:57:25 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
14/4/21, 1:57:53 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights				
Test Date and Time	Test	Measurement	Notes	Result
14/4/21, 1:35:24 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
14/4/21, 1:35:35 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
14/4/21, 1:35:46 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
14/4/21, 1:58:53 pm	Powered Earth Continuity	0.15 Ohms		Pass
14/4/21, 1:58:55 pm	Polarity	OK		Pass
14/4/21, 1:58:57 pm	Circuit Connections	OK		Pass
14/4/21, 1:59:05 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
14/4/21, 1:59:31 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 44				
Cooktop				
Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 8:45:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 8:45:34 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 8:45:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:00:54 am	Powered Earth Continuity	0.19 Ohms		Pass
15/4/21, 9:00:56 am	Polarity	OK		Pass
15/4/21, 9:00:59 am	Circuit Connections	OK		Pass

Unit 44, Cooktop (cont.)

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:01:04 am	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 9:01:18 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 8:46:20 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 8:46:31 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 8:46:46 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 8:57:49 am	Powered Earth Continuity	0.39 Ohms		Pass
15/4/21, 8:57:51 am	Polarity	OK		Pass
15/4/21, 8:57:53 am	Circuit Connections	OK		Pass
15/4/21, 8:58:00 am	RCD Test	28ms at 30mA (0 degrees)		Pass
15/4/21, 8:59:22 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 8:47:06 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 8:47:17 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 8:47:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:02:12 am	Powered Earth Continuity	0.18 Ohms		Pass
15/4/21, 9:02:14 am	Polarity	OK		Pass
15/4/21, 9:02:16 am	Circuit Connections	OK		Pass
15/4/21, 9:02:25 am	RCD Test	30ms at 30mA (0 degrees)		Pass
15/4/21, 9:02:43 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 8:47:44 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 8:47:54 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 8:48:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:04:14 am	Powered Earth Continuity	0.35 Ohms		Pass
15/4/21, 9:04:19 am	Polarity	OK		Pass
15/4/21, 9:04:23 am	Circuit Connections	OK		Pass
15/4/21, 9:04:30 am	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 9:04:59 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 8:48:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 8:48:36 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 8:48:51 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:07:58 am	Powered Earth Continuity	0.22 Ohms		Pass
15/4/21, 9:08:00 am	Polarity	OK		Pass
15/4/21, 9:08:02 am	Circuit Connections	OK		Pass
15/4/21, 9:08:08 am	RCD Test	28ms at 30mA (0 degrees)		Pass
15/4/21, 9:08:43 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 8:49:33 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 8:49:44 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 8:49:56 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:10:20 am	Powered Earth Continuity	0.22 Ohms		Pass

Unit 44, Lights (cont.)

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:10:23 am	Polarity	OK		Pass
15/4/21, 9:10:26 am	Circuit Connections	OK		Pass
15/4/21, 9:10:31 am	RCD Test	23ms at 30mA (0 degrees)		Pass
15/4/21, 9:11:12 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 45

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:41:10 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 9:41:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 9:41:51 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:59:30 am	Powered Earth Continuity	0.21 Ohms		Pass
15/4/21, 9:59:34 am	Polarity	OK		Pass
15/4/21, 9:59:38 am	Circuit Connections	OK		Pass
15/4/21, 9:59:44 am	RCD Test	30ms at 30mA (0 degrees)		Pass
15/4/21, 9:59:55 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:42:36 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 9:42:47 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 9:43:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:53:42 am	Powered Earth Continuity	0.31 Ohms		Pass
15/4/21, 9:53:44 am	Polarity	OK		Pass
15/4/21, 9:53:46 am	Circuit Connections	OK		Pass
15/4/21, 9:53:53 am	RCD Test	23ms at 30mA (0 degrees)		Pass
15/4/21, 9:55:15 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:43:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 9:43:28 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 9:43:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 10:00:48 am	Powered Earth Continuity	0.21 Ohms		Pass
15/4/21, 10:00:50 am	Polarity	OK		Pass
15/4/21, 10:00:52 am	Circuit Connections	OK		Pass
15/4/21, 10:00:59 am	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 10:01:13 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:43:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 9:44:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 9:44:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 10:03:18 am	Powered Earth Continuity	0.32 Ohms		Pass
15/4/21, 10:03:20 am	Polarity	OK		Pass
15/4/21, 10:03:22 am	Circuit Connections	OK		Pass
15/4/21, 10:03:28 am	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 10:05:12 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:44:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 9:45:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 9:45:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 10:08:59 am	Powered Earth Continuity	0.34 Ohms		Pass
15/4/21, 10:09:01 am	Polarity	OK		Pass
15/4/21, 10:09:04 am	Circuit Connections	OK		Pass
15/4/21, 10:09:10 am	RCD Test	28ms at 30mA (0 degrees)		Pass
15/4/21, 10:10:23 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 9:45:47 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 9:45:59 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 9:46:10 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 10:11:42 am	Powered Earth Continuity	0.22 Ohms		Pass
15/4/21, 10:11:46 am	Polarity	OK		Pass
15/4/21, 10:11:48 am	Circuit Connections	OK		Pass
15/4/21, 10:11:56 am	RCD Test	29ms at 30mA (0 degrees)		Pass
15/4/21, 10:12:48 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 46

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 11:53:57 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 11:54:12 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 11:54:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 12:10:31 pm	Powered Earth Continuity	0.16 Ohms		Pass
15/4/21, 12:10:33 pm	Polarity	OK		Pass
15/4/21, 12:10:35 pm	Circuit Connections	OK		Pass
15/4/21, 12:10:43 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 12:10:54 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 11:54:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 11:57:09 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 11:57:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 12:07:11 pm	Powered Earth Continuity	0.37 Ohms		Pass
15/4/21, 12:07:13 pm	Polarity	OK		Pass
15/4/21, 12:07:15 pm	Circuit Connections	OK		Pass
15/4/21, 12:07:21 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 12:08:28 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 11:57:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 11:58:02 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 11:58:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 12:11:27 pm	Powered Earth Continuity	0.16 Ohms		Pass
15/4/21, 12:11:29 pm	Polarity	OK		Pass
15/4/21, 12:11:31 pm	Circuit Connections	OK		Pass

Unit 46, Oven (cont.)

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:11:44 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 12:11:53 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 11:58:57 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 11:59:08 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 11:59:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 12:13:40 pm	Powered Earth Continuity	0.31 Ohms		Pass
15/4/21, 12:13:41 pm	Polarity	OK		Pass
15/4/21, 12:13:43 pm	Circuit Connections	OK		Pass
15/4/21, 12:13:51 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 12:14:21 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 11:59:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 11:59:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 12:00:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 12:16:10 pm	Powered Earth Continuity	0.18 Ohms		Pass
15/4/21, 12:16:13 pm	Polarity	OK		Pass
15/4/21, 12:16:15 pm	Circuit Connections	OK		Pass
15/4/21, 12:16:21 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
15/4/21, 12:16:40 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:00:40 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 12:00:52 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 12:01:02 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 12:17:49 pm	Powered Earth Continuity	0.22 Ohms		Pass
15/4/21, 12:17:52 pm	Polarity	OK		Pass
15/4/21, 12:17:54 pm	Circuit Connections	OK		Pass
15/4/21, 12:18:00 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
15/4/21, 12:18:20 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 47

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:55:41 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 12:55:53 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 12:56:08 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 1:13:09 pm	Powered Earth Continuity	0.18 Ohms		Pass
15/4/21, 1:13:16 pm	Polarity	OK		Pass
15/4/21, 1:13:18 pm	Circuit Connections	OK		Pass
15/4/21, 1:13:25 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 1:13:37 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:56:30 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 12:56:58 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 47, A/C (cont.)

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:57:09 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 1:09:23 pm	Powered Earth Continuity	0.25 Ohms		Pass
15/4/21, 1:09:25 pm	Polarity	OK		Pass
15/4/21, 1:09:30 pm	Circuit Connections	OK		Pass
15/4/21, 1:09:37 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
15/4/21, 1:10:59 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:57:32 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 12:57:44 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 12:57:55 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 1:16:58 pm	Powered Earth Continuity	0.19 Ohms		Pass
15/4/21, 1:16:59 pm	Polarity	OK		Pass
15/4/21, 1:17:03 pm	Circuit Connections	OK		Pass
15/4/21, 1:17:10 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 1:17:28 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:58:14 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 12:58:26 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 12:58:36 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 1:18:01 pm	Powered Earth Continuity	0.19 Ohms		Pass
15/4/21, 1:18:03 pm	Polarity	OK		Pass
15/4/21, 1:18:05 pm	Circuit Connections	OK		Pass
15/4/21, 1:18:14 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
15/4/21, 1:19:38 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:58:53 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 12:59:04 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 12:59:18 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 1:22:25 pm	Powered Earth Continuity	0.26 Ohms		Pass
15/4/21, 1:22:28 pm	Polarity	OK		Pass
15/4/21, 1:22:33 pm	Circuit Connections	OK		Pass
15/4/21, 1:22:41 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
15/4/21, 1:23:28 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
15/4/21, 12:59:39 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
15/4/21, 12:59:50 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
15/4/21, 1:00:00 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
15/4/21, 1:25:06 pm	Powered Earth Continuity	0.29 Ohms		Pass
15/4/21, 1:25:09 pm	Polarity	OK		Pass
15/4/21, 1:25:11 pm	Circuit Connections	OK		Pass
15/4/21, 1:25:18 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
15/4/21, 1:25:38 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 48

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
5/21, 7:23:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 7:23:34 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 7:23:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 7:56:12 am	Powered Earth Continuity	0.20 Ohms		Pass
5/21, 7:56:17 am	Polarity	OK		Pass
5/21, 7:56:22 am	Circuit Connections	OK		Pass
5/21, 7:56:33 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 7:56:50 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/21, 7:24:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 7:24:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 7:24:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 7:54:31 am	Powered Earth Continuity	0.21 Ohms		Pass
5/21, 7:54:38 am	Polarity	OK		Pass
5/21, 7:54:41 am	Circuit Connections	OK		Pass
5/21, 7:55:32 am	RCD Test	30ms at 30mA (0 degrees)		Pass
5/21, 7:55:44 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/21, 7:25:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 7:25:17 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 7:25:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 7:57:19 am	Powered Earth Continuity	0.21 Ohms		Pass
5/21, 7:57:22 am	Polarity	OK		Pass
5/21, 7:57:24 am	Circuit Connections	OK		Pass
5/21, 7:57:32 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 7:57:51 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/21, 7:25:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 7:26:12 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 7:27:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 7:59:21 am	Powered Earth Continuity	0.30 Ohms		Pass
5/21, 7:59:23 am	Polarity	OK		Pass
5/21, 7:59:25 am	Circuit Connections	OK		Pass
5/21, 7:59:32 am	RCD Test	30ms at 30mA (0 degrees)		Pass
5/21, 8:00:33 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/21, 7:26:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 7:26:54 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 7:27:20 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:03:10 am	Powered Earth Continuity	0.53 Ohms		Pass
5/21, 8:03:14 am	Polarity	OK		Pass
5/21, 8:03:16 am	Circuit Connections	OK		Pass

Unit 48, Power 2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:03:23 am	RCD Test	28ms at 30mA (0 degrees)		Pass
5/21, 8:03:58 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/21, 7:28:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 7:28:12 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 7:28:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:06:32 am	Powered Earth Continuity	0.21 Ohms		Pass
5/21, 8:06:34 am	Polarity	OK		Pass
5/21, 8:06:37 am	Circuit Connections	OK		Pass
5/21, 8:06:57 am	RCD Test	30ms at 30mA (0 degrees)		Pass
5/21, 8:07:32 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 49

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:35:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:35:49 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:36:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:49:17 am	Powered Earth Continuity	0.18 Ohms		Pass
5/21, 8:49:22 am	Polarity	OK		Pass
5/21, 8:49:26 am	Circuit Connections	OK		Pass
5/21, 8:49:35 am	RCD Test	30ms at 30mA (0 degrees)		Pass
5/21, 8:49:56 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:36:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:36:37 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:36:54 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:46:09 am	Powered Earth Continuity	0.30 Ohms		Pass
5/21, 8:46:32 am	Polarity	OK		Pass
5/21, 8:46:34 am	Circuit Connections	OK		Pass
5/21, 8:46:40 am	RCD Test	28ms at 30mA (0 degrees)		Pass
5/21, 8:47:56 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:37:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:37:29 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:37:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:50:17 am	Powered Earth Continuity	0.18 Ohms		Pass
5/21, 8:50:20 am	Polarity	OK		Pass
5/21, 8:50:25 am	Circuit Connections	OK		Pass
5/21, 8:50:36 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 8:50:51 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:38:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:38:18 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 49, Power 1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:38:29 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:52:42 am	Powered Earth Continuity	0.26 Ohms		Pass
5/21, 8:52:44 am	Polarity	OK		Pass
5/21, 8:52:46 am	Circuit Connections	OK		Pass
5/21, 8:52:53 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 8:53:55 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:38:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:39:03 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:39:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 8:57:26 am	Powered Earth Continuity	0.49 Ohms		Pass
5/21, 8:57:39 am	Polarity	OK		Pass
5/21, 8:57:42 am	Circuit Connections	OK		Pass
5/21, 8:57:48 am	RCD Test	23ms at 30mA (0 degrees)		Pass
5/21, 8:58:21 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/21, 8:39:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 8:40:05 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 8:40:19 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 9:07:10 am	Powered Earth Continuity	0.19 Ohms		Pass
5/21, 9:07:17 am	Polarity	OK		Pass
5/21, 9:07:19 am	Circuit Connections	OK		Pass
5/21, 9:07:26 am	RCD Test	29ms at 30mA (0 degrees)		Pass
5/21, 9:07:58 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 50

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:45:10 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:45:21 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:45:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:00:55 am	Powered Earth Continuity	0.15 Ohms		Pass
5/21, 10:00:57 am	Polarity	OK		Pass
5/21, 10:00:59 am	Circuit Connections	OK		Pass
5/21, 10:01:18 am	RCD Test	34ms at 30mA (180 degrees)		Pass
5/21, 10:01:37 am	RCD Test	24ms at 30mA (0 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:46:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:46:13 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:46:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 9:55:13 am	Powered Earth Continuity	0.29 Ohms		Pass
5/21, 9:55:15 am	Polarity	OK		Pass
5/21, 9:55:17 am	Circuit Connections	OK		Pass
5/21, 9:55:24 am	RCD Test	28ms at 30mA (0 degrees)		Pass
5/21, 9:57:08 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:46:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:47:06 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:47:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:01:57 am	Powered Earth Continuity	0.17 Ohms		Pass
5/21, 10:01:59 am	Polarity	OK		Pass
5/21, 10:02:01 am	Circuit Connections	OK		Pass
5/21, 10:02:09 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 10:02:27 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:48:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:48:39 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:48:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:04:48 am	Powered Earth Continuity	0.42 Ohms		Pass
5/21, 10:04:50 am	Polarity	OK		Pass
5/21, 10:04:52 am	Circuit Connections	OK		Pass
5/21, 10:04:58 am	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 10:05:37 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:49:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:49:19 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:49:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:09:10 am	Powered Earth Continuity	0.29 Ohms		Pass
5/21, 10:09:12 am	Polarity	OK		Pass
5/21, 10:09:14 am	Circuit Connections	OK		Pass
5/21, 10:09:20 am	RCD Test	23ms at 30mA (0 degrees)		Pass
5/21, 10:10:25 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/21, 9:49:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 9:50:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 9:50:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 10:12:23 am	Powered Earth Continuity	0.20 Ohms		Pass
5/21, 10:12:25 am	Polarity	OK		Pass
5/21, 10:12:28 am	Circuit Connections	OK		Pass
5/21, 10:12:34 am	RCD Test	29ms at 30mA (0 degrees)		Pass
5/21, 10:13:05 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 51

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
5/21, 12:55:20 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 12:55:31 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 12:55:46 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 1:16:38 pm	Powered Earth Continuity	0.18 Ohms		Pass
5/21, 1:16:41 pm	Polarity	OK		Pass
5/21, 1:16:44 pm	Circuit Connections	OK		Pass

Unit 51, Cooktop (cont.)

Test Date and Time	Test	Measurement	Notes	Result
5/21, 1:16:52 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 1:17:01 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/21, 12:58:13 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 12:58:44 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 12:58:59 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 1:12:39 pm	Powered Earth Continuity	0.31 Ohms		Pass
5/21, 1:12:41 pm	Polarity	OK		Pass
5/21, 1:12:43 pm	Circuit Connections	OK		Pass
5/21, 1:12:49 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
5/21, 1:13:58 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/21, 12:59:22 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 12:59:34 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 12:59:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 1:17:34 pm	Powered Earth Continuity	0.16 Ohms		Pass
5/21, 1:17:36 pm	Polarity	OK		Pass
5/21, 1:17:38 pm	Circuit Connections	OK		Pass
5/21, 1:17:46 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 1:17:57 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/21, 1:00:09 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 1:00:21 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 1:00:31 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 1:20:11 pm	Powered Earth Continuity	0.33 Ohms		Pass
5/21, 1:20:13 pm	Polarity	OK		Pass
5/21, 1:20:16 pm	Circuit Connections	OK		Pass
5/21, 1:20:23 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
5/21, 1:21:03 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/21, 1:00:51 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 1:01:02 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 1:01:19 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 1:24:43 pm	Powered Earth Continuity	0.47 Ohms		Pass
5/21, 1:24:45 pm	Polarity	OK		Pass
5/21, 1:24:46 pm	Circuit Connections	OK		Pass
5/21, 1:24:53 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
5/21, 1:26:19 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/21, 1:01:43 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 1:01:57 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 1:02:11 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 1:27:23 pm	Powered Earth Continuity	0.21 Ohms		Pass

Unit 51, Lights (cont.)

Test Date and Time	Test	Measurement	Notes	Result
5/21, 1:27:26 pm	Polarity	OK		Pass
5/21, 1:27:28 pm	Circuit Connections	OK		Pass
5/21, 1:27:35 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
5/21, 1:28:00 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 52

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
5/21, 10:38:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 10:39:06 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 10:39:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 11:59:10 am	Powered Earth Continuity	0.14 Ohms		Pass
5/21, 11:59:14 am	Polarity	OK		Pass
5/21, 11:59:53 am	RCD Test	30ms at 30mA (0 degrees)		Pass
5/21, 12:00:14 pm	RCD Test	33ms at 30mA (180 degrees)		Pass
5/21, 12:02:33 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
5/21, 10:39:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 10:40:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 10:40:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 11:53:15 am	Powered Earth Continuity	0.22 Ohms		Pass
5/21, 11:53:17 am	Polarity	OK		Pass
5/21, 11:53:19 am	Circuit Connections	OK		Pass
5/21, 11:53:46 am	RCD Test	29ms at 30mA (0 degrees)		Pass
5/21, 11:54:55 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
5/21, 10:40:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 10:40:52 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 10:41:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 12:01:22 pm	Powered Earth Continuity	0.15 Ohms		Pass
5/21, 12:01:26 pm	Polarity	OK		Pass
5/21, 12:01:30 pm	Circuit Connections	OK		Pass
5/21, 12:01:43 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
5/21, 12:01:57 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
5/21, 10:41:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 10:41:45 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 10:42:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 12:04:30 pm	Powered Earth Continuity	0.17 Ohms		Pass
5/21, 12:04:33 pm	Polarity	OK		Pass
5/21, 12:04:36 pm	Circuit Connections	OK		Pass
5/21, 12:04:42 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
5/21, 12:05:18 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
5/21, 10:43:12 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 10:43:22 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 10:43:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 12:08:45 pm	Powered Earth Continuity	0.22 Ohms		Pass
5/21, 12:08:49 pm	Polarity	OK		Pass
5/21, 12:08:51 pm	Circuit Connections	OK		Pass
5/21, 12:09:06 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
5/21, 12:09:31 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
5/21, 10:44:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
5/21, 10:44:26 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
5/21, 10:44:37 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
5/21, 12:16:20 pm	Powered Earth Continuity	0.20 Ohms		Pass
5/21, 12:16:23 pm	Polarity	OK		Pass
5/21, 12:16:25 pm	Circuit Connections	OK		Pass
5/21, 12:16:32 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
5/21, 12:17:12 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 53

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
6/21, 7:13:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 7:13:16 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 7:13:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 7:29:09 am	Powered Earth Continuity	0.18 Ohms		Pass
6/21, 7:29:15 am	Polarity	OK		Pass
6/21, 7:29:21 am	Circuit Connections	OK		Pass
6/21, 7:29:35 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 7:30:18 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/21, 7:14:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 7:14:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 7:14:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 7:24:41 am	Powered Earth Continuity	0.26 Ohms		Pass
6/21, 7:24:43 am	Polarity	OK		Pass
6/21, 7:24:45 am	Circuit Connections	OK		Pass
6/21, 7:24:50 am	RCD Test	29ms at 30mA (0 degrees)		Pass
6/21, 7:25:57 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/21, 7:15:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 7:15:14 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 7:15:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 7:30:59 am	Powered Earth Continuity	0.17 Ohms		Pass
6/21, 7:31:02 am	Polarity	OK		Pass
6/21, 7:31:05 am	Circuit Connections	OK		Pass

Unit 53, Oven (cont.)

Test Date and Time	Test	Measurement	Notes	Result
6/21, 7:31:13 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 7:31:27 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
6/21, 7:15:49 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 7:16:00 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 7:16:11 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 7:33:53 am	Powered Earth Continuity	0.23 Ohms		Pass
6/21, 7:33:57 am	Polarity	OK		Pass
6/21, 7:33:59 am	Circuit Connections	OK		Pass
6/21, 7:34:05 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 7:34:30 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
6/21, 7:16:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 7:16:42 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 7:16:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 7:37:31 am	Powered Earth Continuity	0.48 Ohms		Pass
6/21, 7:38:11 am	Polarity	OK		Pass
6/21, 7:38:13 am	Circuit Connections	OK		Pass
6/21, 7:38:20 am	RCD Test	28ms at 30mA (0 degrees)		Pass
6/21, 7:38:46 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/21, 7:17:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 7:17:33 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 7:17:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 7:40:06 am	Powered Earth Continuity	0.15 Ohms		Pass
6/21, 7:40:09 am	Polarity	OK		Pass
6/21, 7:40:12 am	Circuit Connections	OK		Pass
6/21, 7:40:22 am	RCD Test	28ms at 30mA (0 degrees)		Pass
6/21, 7:40:45 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 54

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
6/21, 8:13:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 8:13:34 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 8:13:49 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 8:30:44 am	Powered Earth Continuity	0.12 Ohms		Pass
6/21, 8:30:47 am	Polarity	OK		Pass
6/21, 8:30:49 am	Circuit Connections	OK		Pass
6/21, 8:30:55 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 8:31:14 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/21, 8:14:12 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 8:14:23 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 54, A/C (cont.)

Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 8:14:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 8:26:34 am	Powered Earth Continuity	0.34 Ohms		Pass
6/5/21, 8:26:36 am	Polarity	OK		Pass
6/5/21, 8:26:38 am	Circuit Connections	OK		Pass
6/5/21, 8:26:44 am	RCD Test	28ms at 30mA (0 degrees)		Pass
6/5/21, 8:27:49 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 8:15:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 8:15:12 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 8:15:22 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 8:31:53 am	Powered Earth Continuity	0.11 Ohms		Pass
6/5/21, 8:31:55 am	Polarity	OK		Pass
6/5/21, 8:31:57 am	Circuit Connections	OK		Pass
6/5/21, 8:32:04 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/5/21, 8:32:18 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 8:15:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 8:15:52 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 8:16:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 8:34:03 am	Powered Earth Continuity	0.22 Ohms		Pass
6/5/21, 8:34:05 am	Polarity	OK		Pass
6/5/21, 8:34:08 am	Circuit Connections	OK		Pass
6/5/21, 8:34:15 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/5/21, 8:34:50 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 8:16:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 8:16:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 8:16:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 8:38:31 am	Powered Earth Continuity	0.51 Ohms		Pass
6/5/21, 8:38:33 am	Polarity	OK		Pass
6/5/21, 8:38:36 am	Circuit Connections	OK		Pass
6/5/21, 8:38:43 am	RCD Test	28ms at 30mA (0 degrees)		Pass
6/5/21, 8:40:03 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 8:17:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 8:17:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 8:17:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 8:42:04 am	Powered Earth Continuity	0.16 Ohms		Pass
6/5/21, 8:42:06 am	Polarity	OK		Pass
6/5/21, 8:42:09 am	Circuit Connections	OK		Pass
6/5/21, 8:42:17 am	RCD Test	29ms at 30mA (0 degrees)		Pass
6/5/21, 8:43:07 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 55

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
6/21, 1:01:36 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 1:01:47 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 1:02:24 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 1:19:40 pm	Powered Earth Continuity	0.06 Ohms		Pass
6/21, 1:19:43 pm	Polarity	OK		Pass
6/21, 1:19:47 pm	Circuit Connections	OK		Pass
6/21, 1:19:53 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
6/21, 1:20:07 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/21, 1:02:50 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 1:03:01 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 1:03:15 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 1:16:15 pm	Powered Earth Continuity	0.23 Ohms		Pass
6/21, 1:16:17 pm	Polarity	OK		Pass
6/21, 1:16:20 pm	Circuit Connections	OK		Pass
6/21, 1:16:26 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
6/21, 1:17:20 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/21, 1:03:36 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 1:03:47 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 1:03:57 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 1:20:29 pm	Powered Earth Continuity	0.06 Ohms		Pass
6/21, 1:20:31 pm	Polarity	OK		Pass
6/21, 1:20:42 pm	Circuit Connections	OK		Pass
6/21, 1:20:56 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
6/21, 1:24:00 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
6/21, 1:04:27 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 1:04:41 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 1:04:54 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 1:25:40 pm	Powered Earth Continuity	0.37 Ohms		Pass
6/21, 1:25:43 pm	Polarity	OK		Pass
6/21, 1:25:46 pm	Circuit Connections	OK		Pass
6/21, 1:25:52 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
6/21, 1:26:30 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
6/21, 1:05:44 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 1:05:55 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 1:06:12 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 1:29:20 pm	Powered Earth Continuity	0.16 Ohms		Pass
6/21, 1:29:23 pm	Polarity	OK		Pass
6/21, 1:29:25 pm	Circuit Connections	OK		Pass

Unit 55, Power 2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
6/21, 1:29:31 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
6/21, 1:30:08 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/21, 1:06:35 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 1:06:47 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 1:06:57 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 1:31:54 pm	Powered Earth Continuity	0.28 Ohms		Pass
6/21, 1:31:56 pm	Polarity	OK		Pass
6/21, 1:32:00 pm	Circuit Connections	OK		Pass
6/21, 1:32:06 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
6/21, 1:32:43 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 56

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
6/21, 10:31:31 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 10:31:43 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 10:32:08 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 11:53:02 am	Powered Earth Continuity	0.15 Ohms		Pass
6/21, 11:53:04 am	Polarity	OK		Pass
6/21, 11:53:06 am	Circuit Connections	OK		Pass
6/21, 11:53:19 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 11:53:30 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/21, 10:32:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 10:32:37 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 10:33:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 11:49:56 am	Powered Earth Continuity	0.39 Ohms		Pass
6/21, 11:49:58 am	Polarity	OK		Pass
6/21, 11:50:00 am	Circuit Connections	OK		Pass
6/21, 11:50:08 am	RCD Test	28ms at 30mA (0 degrees)		Pass
6/21, 11:51:10 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
6/21, 10:33:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 10:33:37 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 10:33:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 11:54:05 am	Powered Earth Continuity	0.12 Ohms		Pass
6/21, 11:54:07 am	Polarity	OK		Pass
6/21, 11:54:10 am	Circuit Connections	OK		Pass
6/21, 11:54:15 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 11:54:27 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
6/21, 10:34:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 10:34:25 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 56, Power 1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
6/21, 10:34:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 11:56:20 am	Powered Earth Continuity	0.30 Ohms		Pass
6/21, 11:56:22 am	Polarity	OK		Pass
6/21, 11:56:25 am	Circuit Connections	OK		Pass
6/21, 11:56:31 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 11:56:55 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
6/21, 10:34:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 10:35:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 10:35:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 12:06:28 pm	Powered Earth Continuity	0.33 Ohms		Pass
6/21, 12:06:31 pm	Polarity	OK		Pass
6/21, 12:06:33 pm	Circuit Connections	OK		Pass
6/21, 12:06:42 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
6/21, 12:07:18 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
6/21, 10:35:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 10:36:09 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 10:36:20 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 12:17:04 pm	Powered Earth Continuity	0.29 Ohms		Pass
6/21, 12:17:06 pm	Polarity	OK		Pass
6/21, 12:17:10 pm	Circuit Connections	OK		Pass
6/21, 12:17:17 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 12:17:44 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 57

Cooktop

Test Date and Time	Test	Measurement	Notes	Result
6/21, 9:20:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 9:20:14 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 9:20:31 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 9:35:24 am	Powered Earth Continuity	0.13 Ohms		Pass
6/21, 9:35:26 am	Polarity	OK		Pass
6/21, 9:35:33 am	Circuit Connections	OK		Pass
6/21, 9:35:43 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/21, 9:35:58 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
6/21, 9:20:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/21, 9:21:09 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/21, 9:21:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/21, 9:30:20 am	Powered Earth Continuity	0.45 Ohms		Pass
6/21, 9:30:22 am	Polarity	OK		Pass
6/21, 9:30:24 am	Circuit Connections	OK		Pass
6/21, 9:30:29 am	RCD Test	23ms at 30mA (0 degrees)		Pass
6/21, 9:31:49 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven				
Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 9:21:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 9:21:58 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 9:22:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 9:36:24 am	Powered Earth Continuity	0.13 Ohms		Pass
6/5/21, 9:36:34 am	Polarity	OK		Pass
6/5/21, 9:36:37 am	Circuit Connections	OK		Pass
6/5/21, 9:36:44 am	RCD Test	30ms at 30mA (0 degrees)		Pass
6/5/21, 9:36:55 am	RCD Test	34ms at 30mA (180 degrees)		Pass
Power 1				
Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 9:22:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 9:22:54 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 9:23:11 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 9:38:33 am	Powered Earth Continuity	0.21 Ohms		Pass
6/5/21, 9:38:35 am	Polarity	OK		Pass
6/5/21, 9:38:38 am	Circuit Connections	OK		Pass
6/5/21, 9:38:45 am	RCD Test	29ms at 30mA (0 degrees)		Pass
6/5/21, 9:39:11 am	RCD Test	34ms at 30mA (180 degrees)		Pass
Power 2				
Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 9:23:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 9:23:41 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 9:23:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 9:42:17 am	Powered Earth Continuity	0.15 Ohms		Pass
6/5/21, 9:42:19 am	Polarity	OK		Pass
6/5/21, 9:42:21 am	Circuit Connections	OK		Pass
6/5/21, 9:42:27 am	RCD Test	28ms at 30mA (0 degrees)		Pass
6/5/21, 9:42:40 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Lights				
Test Date and Time	Test	Measurement	Notes	Result
6/5/21, 9:24:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
6/5/21, 9:24:34 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
6/5/21, 9:24:44 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
6/5/21, 9:51:18 am	Powered Earth Continuity	0.18 Ohms		Pass
6/5/21, 9:51:20 am	Polarity	OK		Pass
6/5/21, 9:51:23 am	Circuit Connections	OK		Pass
6/5/21, 9:51:30 am	RCD Test	29ms at 30mA (0 degrees)		Pass
6/5/21, 9:52:05 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Unit 58				
Hot Plate				
Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:06:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 8:07:07 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 8:07:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 8:32:14 am	Powered Earth Continuity	0.09 Ohms		Pass
24/5/21, 8:32:19 am	Polarity	OK		Pass
24/5/21, 8:32:21 am	Circuit Connections	OK		Pass

Unit 58, Hot Plate (cont.)

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:32:28 am	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 8:32:39 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:07:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 8:07:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 8:08:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 8:24:47 am	Powered Earth Continuity	0.07 Ohms		Pass
24/5/21, 8:24:50 am	Polarity	OK		Pass
24/5/21, 8:24:52 am	Circuit Connections	OK		Pass
24/5/21, 8:24:58 am	RCD Test	29ms at 30mA (0 degrees)		Pass
24/5/21, 8:26:03 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:08:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 8:08:50 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 8:09:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 8:33:08 am	Powered Earth Continuity	0.13 Ohms		Pass
24/5/21, 8:33:10 am	Polarity	OK		Pass
24/5/21, 8:33:13 am	Circuit Connections	OK		Pass
24/5/21, 8:33:20 am	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 8:33:33 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:10:10 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 8:10:22 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 8:10:31 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 8:37:32 am	Powered Earth Continuity	0.09 Ohms		Pass
24/5/21, 8:37:34 am	Polarity	OK		Pass
24/5/21, 8:37:36 am	Circuit Connections	OK		Pass
24/5/21, 8:37:43 am	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 8:38:11 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:10:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 8:11:02 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 8:11:17 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 8:41:51 am	Powered Earth Continuity	0.34 Ohms		Pass
24/5/21, 8:41:54 am	Polarity	OK		Pass
24/5/21, 8:41:57 am	Circuit Connections	OK		Pass
24/5/21, 8:42:05 am	RCD Test	29ms at 30mA (0 degrees)		Pass
24/5/21, 8:42:50 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:11:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 8:12:25 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 8:12:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 8:44:08 am	Powered Earth Continuity	0.10 Ohms		Pass

Unit 58, Lights (cont.)

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 8:44:11 am	Polarity	OK		Pass
24/5/21, 8:44:13 am	Circuit Connections	OK		Pass
24/5/21, 8:44:20 am	RCD Test	29ms at 30mA (0 degrees)		Pass
24/5/21, 8:44:49 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 59

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 9:25:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 9:26:12 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 9:26:29 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 9:40:06 am	Powered Earth Continuity	<0.03 Ohms		Pass
24/5/21, 9:40:11 am	Polarity	OK		Pass
24/5/21, 9:40:16 am	Circuit Connections	OK		Pass
24/5/21, 9:40:25 am	RCD Test	24ms at 30mA (0 degrees)		Pass
24/5/21, 9:40:41 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 9:26:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 9:26:58 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 9:27:19 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 9:36:15 am	Powered Earth Continuity	0.18 Ohms		Pass
24/5/21, 9:36:18 am	Polarity	OK		Pass
24/5/21, 9:36:20 am	Circuit Connections	OK		Pass
24/5/21, 9:36:27 am	RCD Test	28ms at 30mA (0 degrees)		Pass
24/5/21, 9:37:45 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 9:27:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 9:27:50 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 9:28:02 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 9:41:19 am	Powered Earth Continuity	<0.03 Ohms		Pass
24/5/21, 9:41:22 am	Polarity	OK		Pass
24/5/21, 9:41:24 am	Circuit Connections	OK		Pass
24/5/21, 9:41:30 am	RCD Test	24ms at 30mA (0 degrees)		Pass
24/5/21, 9:41:43 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 9:28:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 9:28:33 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 9:28:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 9:44:51 am	Powered Earth Continuity	0.07 Ohms		Pass
24/5/21, 9:44:53 am	Polarity	OK		Pass
24/5/21, 9:44:56 am	Circuit Connections	OK		Pass
24/5/21, 9:45:03 am	RCD Test	24ms at 30mA (0 degrees)		Pass
24/5/21, 9:45:45 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 9:29:06 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 9:29:18 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 9:29:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 9:50:32 am	Powered Earth Continuity	0.34 Ohms		Pass
24/5/21, 9:50:44 am	Polarity	OK		Pass
24/5/21, 9:50:47 am	Circuit Connections	OK		Pass
24/5/21, 9:50:53 am	RCD Test	28ms at 30mA (0 degrees)		Pass
24/5/21, 9:51:54 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 9:29:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 9:30:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 9:30:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 9:53:48 am	Powered Earth Continuity	0.04 Ohms		Pass
24/5/21, 9:53:50 am	Polarity	OK		Pass
24/5/21, 9:53:52 am	Circuit Connections	OK		Pass
24/5/21, 9:54:00 am	RCD Test	23ms at 30mA (0 degrees)		Pass
24/5/21, 9:54:33 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 60

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 10:28:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 10:28:40 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 10:29:02 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 10:43:02 am	Powered Earth Continuity	<0.03 Ohms		Pass
24/5/21, 10:43:09 am	Polarity	OK		Pass
24/5/21, 10:43:11 am	Circuit Connections	OK		Pass
24/5/21, 10:43:19 am	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 10:43:28 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 10:29:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 10:29:38 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 10:29:52 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 11:49:42 am	Powered Earth Continuity	0.11 Ohms		Pass
24/5/21, 11:49:49 am	Polarity	OK		Pass
24/5/21, 11:49:52 am	Circuit Connections	OK		Pass
24/5/21, 11:49:59 am	RCD Test	28ms at 30mA (0 degrees)		Pass
24/5/21, 11:51:21 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 10:30:34 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 10:30:45 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 10:30:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 10:43:50 am	Powered Earth Continuity	<0.03 Ohms		Pass
24/5/21, 10:43:52 am	Polarity	OK		Pass
24/5/21, 10:43:54 am	Circuit Connections	OK		Pass

Unit 60, Oven (cont.)

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 10:44:01 am	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 10:44:12 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 10:31:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 10:31:25 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 10:31:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 10:45:44 am	Powered Earth Continuity	0.26 Ohms		Pass
24/5/21, 10:45:47 am	Polarity	OK		Pass
24/5/21, 10:45:56 am	Circuit Connections	OK		Pass
24/5/21, 10:46:03 am	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 10:46:38 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 10:31:53 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 10:32:03 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 10:32:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 11:43:39 am	Powered Earth Continuity	0.17 Ohms		Pass
24/5/21, 11:43:41 am	Polarity	OK		Pass
24/5/21, 11:43:43 am	Circuit Connections	OK		Pass
24/5/21, 11:43:49 am	RCD Test	28ms at 30mA (0 degrees)		Pass
24/5/21, 11:44:33 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 10:32:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 10:32:49 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 10:32:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 11:45:46 am	Powered Earth Continuity	0.06 Ohms		Pass
24/5/21, 11:45:48 am	Polarity	OK		Pass
24/5/21, 11:45:49 am	Circuit Connections	OK		Pass
24/5/21, 11:45:55 am	RCD Test	29ms at 30mA (0 degrees)		Pass
24/5/21, 11:46:21 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 61

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 12:21:55 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 12:22:08 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 12:22:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 12:36:32 pm	Powered Earth Continuity	<0.03 Ohms		Pass
24/5/21, 12:36:35 pm	Polarity	OK		Pass
24/5/21, 12:36:37 pm	Circuit Connections	OK		Pass
24/5/21, 12:36:43 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 12:36:58 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 12:22:49 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 12:23:01 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 61, A/C (cont.)

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 12:23:16 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 12:31:46 pm	Powered Earth Continuity	0.24 Ohms		Pass
24/5/21, 12:31:48 pm	Polarity	OK		Pass
24/5/21, 12:31:51 pm	Circuit Connections	OK		Pass
24/5/21, 12:31:57 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
24/5/21, 12:33:28 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 12:23:35 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 12:23:46 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 12:23:56 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 12:37:31 pm	Powered Earth Continuity	<0.03 Ohms		Pass
24/5/21, 12:37:34 pm	Polarity	OK		Pass
24/5/21, 12:37:36 pm	Circuit Connections	OK		Pass
24/5/21, 12:37:44 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 12:37:59 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 12:24:22 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 12:24:34 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 12:24:44 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 12:40:50 pm	Powered Earth Continuity	0.13 Ohms		Pass
24/5/21, 12:40:52 pm	Polarity	OK		Pass
24/5/21, 12:40:54 pm	Circuit Connections	OK		Pass
24/5/21, 12:41:02 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
24/5/21, 12:41:31 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 12:25:01 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 12:25:36 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 12:25:46 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 12:45:24 pm	Powered Earth Continuity	0.32 Ohms		Pass
24/5/21, 12:45:27 pm	Polarity	OK		Pass
24/5/21, 12:45:37 pm	Circuit Connections	OK		Pass
24/5/21, 12:45:45 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
24/5/21, 12:46:21 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 12:26:02 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 12:26:13 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 12:26:22 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 12:49:42 pm	Powered Earth Continuity	0.07 Ohms		Pass
24/5/21, 12:49:45 pm	Polarity	OK		Pass
24/5/21, 12:49:48 pm	Circuit Connections	OK		Pass
24/5/21, 12:49:57 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
24/5/21, 12:50:28 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 62

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 1:39:02 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 1:39:13 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 1:39:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 1:59:39 pm	Powered Earth Continuity	0.07 Ohms		Pass
24/5/21, 1:59:42 pm	Polarity	OK		Pass
24/5/21, 1:59:44 pm	Circuit Connections	OK		Pass
24/5/21, 2:00:30 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
24/5/21, 2:00:52 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 1:39:55 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 1:40:07 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 1:40:21 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 1:49:47 pm	Powered Earth Continuity	0.13 Ohms		Pass
24/5/21, 1:49:49 pm	Polarity	OK		Pass
24/5/21, 1:49:51 pm	Circuit Connections	OK		Pass
24/5/21, 1:50:00 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
24/5/21, 1:51:52 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 1:40:41 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 1:40:54 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 1:41:18 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 2:01:16 pm	Powered Earth Continuity	0.09 Ohms		Pass
24/5/21, 2:01:17 pm	Polarity	OK		Pass
24/5/21, 2:01:20 pm	Circuit Connections	OK		Pass
24/5/21, 2:01:26 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
24/5/21, 2:01:37 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 1:41:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 1:41:51 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 1:42:03 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 2:03:16 pm	Powered Earth Continuity	0.07 Ohms		Pass
24/5/21, 2:03:19 pm	Polarity	OK		Pass
24/5/21, 2:03:21 pm	Circuit Connections	OK		Pass
24/5/21, 2:03:26 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
24/5/21, 2:03:48 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 1:42:23 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 1:42:33 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 1:42:43 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
24/5/21, 2:08:31 pm	Powered Earth Continuity	0.27 Ohms		Fail
24/5/21, 2:08:33 pm	Polarity	OK		Pass
24/5/21, 2:08:35 pm	Circuit Connections	OK		Pass

Unit 62, Power 2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 2:08:45 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
24/5/21, 2:09:11 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
24/5/21, 1:43:01 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
24/5/21, 1:43:12 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
24/5/21, 1:43:21 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 6:49:03 am	Powered Earth Continuity	0.11 Ohms		Pass
25/5/21, 6:49:05 am	Polarity	OK		Pass
25/5/21, 6:49:07 am	Circuit Connections	OK		Pass
25/5/21, 6:49:14 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 6:49:37 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 63

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 7:18:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 7:18:19 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 7:18:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 7:35:21 am	Powered Earth Continuity	0.04 Ohms		Pass
25/5/21, 7:35:23 am	Polarity	OK		Pass
25/5/21, 7:35:25 am	Circuit Connections	OK		Pass
25/5/21, 7:35:36 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 7:35:49 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 7:18:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 7:19:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 7:19:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 7:31:21 am	Powered Earth Continuity	0.08 Ohms		Pass
25/5/21, 7:31:22 am	Polarity	OK		Pass
25/5/21, 7:31:24 am	Circuit Connections	OK		Pass
25/5/21, 7:31:30 am	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 7:33:10 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 7:19:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 7:19:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 7:20:19 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 7:36:19 am	Powered Earth Continuity	<0.03 Ohms		Pass
25/5/21, 7:36:21 am	Polarity	OK		Pass
25/5/21, 7:36:24 am	Circuit Connections	OK		Pass
25/5/21, 7:36:31 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 7:36:41 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 7:20:36 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 7:20:48 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 63, Power 1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 7:20:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 7:39:16 am	Powered Earth Continuity	0.11 Ohms		Pass
25/5/21, 7:39:21 am	Polarity	OK		Pass
25/5/21, 7:39:23 am	Circuit Connections	OK		Pass
25/5/21, 7:39:29 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 7:39:51 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 7:21:15 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 7:21:26 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 7:21:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 7:42:38 am	Powered Earth Continuity	0.33 Ohms		Pass
25/5/21, 7:42:38 am	Polarity	OK		Pass
25/5/21, 7:43:02 am	Circuit Connections	OK		Pass
25/5/21, 7:43:08 am	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 7:43:33 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 7:21:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 7:22:30 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 7:22:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 8:01:03 am	Powered Earth Continuity	0.07 Ohms		Pass
25/5/21, 8:01:05 am	Polarity	OK		Pass
25/5/21, 8:01:08 am	Circuit Connections	OK		Pass
25/5/21, 8:01:23 am	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 8:01:49 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 64

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 8:41:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 8:41:59 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 8:42:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 8:55:35 am	Powered Earth Continuity	0.06 Ohms		Pass
25/5/21, 8:55:39 am	Polarity	OK		Pass
25/5/21, 8:55:41 am	Circuit Connections	OK		Pass
25/5/21, 8:55:48 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 8:56:15 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 8:42:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 8:43:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 8:43:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 8:52:17 am	Powered Earth Continuity	0.11 Ohms		Pass
25/5/21, 8:52:49 am	Polarity	OK		Pass
25/5/21, 8:52:51 am	Circuit Connections	OK		Pass
25/5/21, 8:52:57 am	RCD Test	28ms at 30mA (0 degrees)		Pass
25/5/21, 8:53:49 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 8:43:46 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 8:43:57 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 8:44:07 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 8:57:00 am	Powered Earth Continuity	0.04 Ohms		Pass
25/5/21, 8:57:02 am	Polarity	OK		Pass
25/5/21, 8:57:05 am	Circuit Connections	OK		Pass
25/5/21, 8:57:10 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 8:57:28 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 8:44:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 8:44:38 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 8:44:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 8:59:20 am	Powered Earth Continuity	0.09 Ohms		Pass
25/5/21, 8:59:23 am	Polarity	OK		Pass
25/5/21, 8:59:25 am	Circuit Connections	OK		Pass
25/5/21, 8:59:32 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 8:59:55 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 8:45:09 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 8:45:22 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 8:45:36 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 9:02:44 am	Powered Earth Continuity	0.34 Ohms		Pass
25/5/21, 9:02:47 am	Polarity	OK		Pass
25/5/21, 9:02:49 am	Circuit Connections	OK		Pass
25/5/21, 9:02:57 am	RCD Test	28ms at 30mA (0 degrees)		Pass
25/5/21, 9:03:24 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 8:45:58 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 8:46:08 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 8:46:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 9:05:16 am	Powered Earth Continuity	0.08 Ohms		Pass
25/5/21, 9:05:18 am	Polarity	OK		Pass
25/5/21, 9:05:20 am	Circuit Connections	OK		Pass
25/5/21, 9:05:26 am	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 9:05:49 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 65

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 9:35:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 9:35:19 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 9:35:40 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 9:49:10 am	Powered Earth Continuity	0.10 Ohms		Pass
25/5/21, 9:49:12 am	Polarity	OK		Pass
25/5/21, 9:49:14 am	Circuit Connections	OK		Pass

Unit 65, Hot Plate (cont.)

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 9:49:22 am	RCD Test	24ms at 30mA (0 degrees)		Pass
25/5/21, 9:49:35 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 9:35:59 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 9:36:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 9:36:30 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 9:45:27 am	Powered Earth Continuity	0.07 Ohms		Pass
25/5/21, 9:45:42 am	Polarity	OK		Pass
25/5/21, 9:45:45 am	Circuit Connections	OK		Pass
25/5/21, 9:45:50 am	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 9:46:52 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 9:36:49 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 9:37:00 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 9:37:23 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 9:50:05 am	Powered Earth Continuity	0.08 Ohms		Pass
25/5/21, 9:50:07 am	Polarity	OK		Pass
25/5/21, 9:50:09 am	Circuit Connections	OK		Pass
25/5/21, 9:50:16 am	RCD Test	24ms at 30mA (0 degrees)		Pass
25/5/21, 9:50:27 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 9:37:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 9:37:52 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 9:38:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 9:52:30 am	Powered Earth Continuity	0.33 Ohms		Pass
25/5/21, 9:52:32 am	Polarity	OK		Pass
25/5/21, 9:52:34 am	Circuit Connections	OK		Pass
25/5/21, 9:52:40 am	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 9:53:11 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 9:38:20 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 9:38:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 9:38:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 9:56:30 am	Powered Earth Continuity	0.18 Ohms		Pass
25/5/21, 9:56:32 am	Polarity	OK		Pass
25/5/21, 9:56:34 am	Circuit Connections	OK		Pass
25/5/21, 9:56:39 am	RCD Test	28ms at 30mA (0 degrees)		Pass
25/5/21, 9:57:47 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 9:39:15 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 9:39:26 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 9:39:39 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 10:01:53 am	Powered Earth Continuity	0.10 Ohms		Pass

Unit 65, Lights (cont.)

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 10:01:55 am	Polarity	OK		Pass
25/5/21, 10:01:57 am	Circuit Connections	OK		Pass
25/5/21, 10:02:02 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 10:02:25 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 66

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 10:33:14 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 10:33:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 10:33:43 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 11:56:50 am	Powered Earth Continuity	0.11 Ohms		Pass
25/5/21, 11:56:52 am	Polarity	OK		Pass
25/5/21, 11:56:54 am	Circuit Connections	OK		Pass
25/5/21, 11:57:02 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 11:58:24 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 10:34:16 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 10:36:24 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 10:36:47 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 10:45:42 am	Powered Earth Continuity	0.07 Ohms		Pass
25/5/21, 10:45:43 am	Polarity	OK		Pass
25/5/21, 10:45:45 am	Circuit Connections	OK		Pass
25/5/21, 10:45:51 am	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 10:47:06 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 10:37:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 10:37:22 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 10:37:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 11:58:55 am	Powered Earth Continuity	0.12 Ohms		Pass
25/5/21, 11:58:57 am	Polarity	OK		Pass
25/5/21, 11:58:59 am	Circuit Connections	OK		Pass
25/5/21, 11:59:20 am	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 11:59:38 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 10:37:51 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 10:38:02 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 10:38:11 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 12:01:25 pm	Powered Earth Continuity	0.23 Ohms		Pass
25/5/21, 12:01:27 pm	Polarity	OK		Pass
25/5/21, 12:01:29 pm	Circuit Connections	OK		Pass
25/5/21, 12:01:36 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 12:02:26 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 10:38:28 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 10:38:39 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 10:39:06 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 12:06:09 pm	Powered Earth Continuity	0.32 Ohms		Pass
25/5/21, 12:06:11 pm	Polarity	OK		Pass
25/5/21, 12:06:13 pm	Circuit Connections	OK		Pass
25/5/21, 12:06:19 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
25/5/21, 12:06:45 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 10:39:32 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 10:39:45 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 10:39:55 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 12:08:44 pm	Powered Earth Continuity	0.10 Ohms		Pass
25/5/21, 12:08:46 pm	Polarity	OK		Pass
25/5/21, 12:08:48 pm	Circuit Connections	OK		Pass
25/5/21, 12:08:53 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
25/5/21, 12:09:36 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 67

Hot Plate

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 12:39:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 12:39:49 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 12:40:08 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 1:11:20 pm	Powered Earth Continuity	0.06 Ohms		Pass
25/5/21, 1:11:23 pm	Polarity	OK		Pass
25/5/21, 1:11:25 pm	Circuit Connections	OK		Pass
25/5/21, 1:11:30 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 1:11:41 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 12:40:41 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 12:41:04 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 12:41:18 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 1:07:17 pm	Powered Earth Continuity	0.10 Ohms		Pass
25/5/21, 1:07:19 pm	Polarity	OK		Pass
25/5/21, 1:07:22 pm	Circuit Connections	OK		Pass
25/5/21, 1:07:29 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 1:08:47 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 12:41:37 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 12:41:48 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 12:42:00 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 1:12:05 pm	Powered Earth Continuity	0.09 Ohms		Pass
25/5/21, 1:12:08 pm	Polarity	OK		Pass
25/5/21, 1:12:10 pm	Circuit Connections	OK		Pass

Unit 67, Oven (cont.)

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 1:12:16 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
25/5/21, 1:12:28 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 12:42:16 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 12:42:27 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 12:42:39 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 1:16:51 pm	Powered Earth Continuity	0.08 Ohms		Pass
25/5/21, 1:16:53 pm	Polarity	OK		Pass
25/5/21, 1:16:55 pm	Circuit Connections	OK		Pass
25/5/21, 1:20:26 pm	RCD Test	24ms at 30mA (0 degrees)		Pass
25/5/21, 1:21:20 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 12:42:57 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 12:43:10 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 12:43:25 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 1:23:27 pm	Powered Earth Continuity	0.08 Ohms		Pass
25/5/21, 1:23:29 pm	Polarity	OK		Pass
25/5/21, 1:23:31 pm	Circuit Connections	OK		Pass
25/5/21, 1:23:37 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
25/5/21, 1:23:56 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
25/5/21, 12:43:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
25/5/21, 12:44:00 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
25/5/21, 12:44:11 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
25/5/21, 1:26:54 pm	Powered Earth Continuity	0.09 Ohms		Pass
25/5/21, 1:26:57 pm	Polarity	OK		Pass
25/5/21, 1:26:59 pm	Circuit Connections	OK		Pass
25/5/21, 1:27:07 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
25/5/21, 1:27:27 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 68

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 7:13:03 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 7:13:14 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 7:13:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 7:25:30 am	Powered Earth Continuity	<0.03 Ohms		Pass
2/6/21, 7:25:35 am	Polarity	OK		Pass
2/6/21, 7:25:38 am	Circuit Connections	OK		Pass
2/6/21, 7:25:51 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 7:26:06 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 7:13:50 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 7:14:03 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 68, A/C (cont.)

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 7:14:18 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 7:21:05 am	Powered Earth Continuity	<0.03 Ohms		Pass
2/6/21, 7:21:07 am	Polarity	OK		Pass
2/6/21, 7:21:09 am	Circuit Connections	OK		Pass
2/6/21, 7:21:16 am	RCD Test	28ms at 30mA (0 degrees)		Pass
2/6/21, 7:22:17 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 7:14:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 7:14:52 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 7:15:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 7:26:35 am	Powered Earth Continuity	0.06 Ohms		Pass
2/6/21, 7:26:37 am	Polarity	OK		Pass
2/6/21, 7:26:39 am	Circuit Connections	OK		Pass
2/6/21, 7:26:46 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 7:26:59 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 7:15:21 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 7:15:32 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 7:15:42 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 7:28:16 am	Powered Earth Continuity	<0.03 Ohms		Pass
2/6/21, 7:28:20 am	Polarity	OK		Pass
2/6/21, 7:28:22 am	Circuit Connections	OK		Pass
2/6/21, 7:28:28 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 7:28:51 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 7:16:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 7:16:11 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 7:16:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 7:31:31 am	Powered Earth Continuity	0.28 Ohms		Pass
2/6/21, 7:31:33 am	Polarity	OK		Pass
2/6/21, 7:31:35 am	Circuit Connections	OK		Pass
2/6/21, 7:31:42 am	RCD Test	23ms at 30mA (0 degrees)		Pass
2/6/21, 7:32:19 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 7:16:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 7:16:55 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 7:17:04 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 7:36:06 am	Powered Earth Continuity	<0.03 Ohms		Pass
2/6/21, 7:36:09 am	Polarity	OK		Pass
2/6/21, 7:36:13 am	Circuit Connections	OK		Pass
2/6/21, 7:36:20 am	RCD Test	29ms at 30mA (0 degrees)		Pass
2/6/21, 7:37:02 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 69

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 8:15:27 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 8:15:44 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 8:16:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 8:41:51 am	Powered Earth Continuity	<0.03 Ohms		Pass
2/6/21, 8:41:53 am	Polarity	OK		Pass
2/6/21, 8:41:55 am	Circuit Connections	OK		Pass
2/6/21, 8:42:01 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 8:42:23 am	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 8:16:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 8:16:37 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 8:16:52 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 8:31:21 am	Powered Earth Continuity	0.07 Ohms		Pass
2/6/21, 8:31:23 am	Polarity	OK		Pass
2/6/21, 8:31:25 am	Circuit Connections	OK		Pass
2/6/21, 8:31:31 am	RCD Test	23ms at 30mA (0 degrees)		Pass
2/6/21, 8:32:32 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 8:17:20 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 8:17:31 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 8:17:51 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 8:42:54 am	Powered Earth Continuity	<0.03 Ohms		Pass
2/6/21, 8:42:56 am	Polarity	OK		Pass
2/6/21, 8:42:59 am	Circuit Connections	OK		Pass
2/6/21, 8:43:06 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 8:43:18 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 8:18:13 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 8:18:23 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 8:18:35 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 8:46:38 am	Powered Earth Continuity	0.11 Ohms		Pass
2/6/21, 8:46:40 am	Polarity	OK		Pass
2/6/21, 8:46:42 am	Circuit Connections	OK		Pass
2/6/21, 8:46:48 am	RCD Test	29ms at 30mA (0 degrees)		Pass
2/6/21, 8:47:19 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 8:18:52 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 8:19:04 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 8:19:16 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 8:50:41 am	Powered Earth Continuity	0.36 Ohms		Pass
2/6/21, 8:50:43 am	Polarity	OK		Pass
2/6/21, 8:50:45 am	Circuit Connections	OK		Pass

Unit 69, Power 2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 8:50:51 am	RCD Test	28ms at 30mA (0 degrees)		Pass
2/6/21, 8:51:41 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 8:19:38 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 8:19:50 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 8:20:01 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 8:57:38 am	Powered Earth Continuity	0.08 Ohms		Pass
2/6/21, 8:57:41 am	Polarity	OK		Pass
2/6/21, 8:57:43 am	Circuit Connections	OK		Pass
2/6/21, 8:57:54 am	RCD Test	29ms at 30mA (0 degrees)		Pass
2/6/21, 8:58:37 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Unit 70

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 9:34:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 9:34:10 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 9:34:25 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 9:48:19 am	Powered Earth Continuity	0.17 Ohms		Pass
2/6/21, 9:48:22 am	Polarity	OK		Pass
2/6/21, 9:48:24 am	Circuit Connections	OK		Pass
2/6/21, 9:48:30 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 9:48:43 am	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 9:34:45 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 9:34:58 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 9:35:24 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 9:45:26 am	Powered Earth Continuity	0.15 Ohms		Pass
2/6/21, 9:45:28 am	Polarity	OK		Pass
2/6/21, 9:45:30 am	Circuit Connections	OK		Pass
2/6/21, 9:45:35 am	RCD Test	29ms at 30mA (0 degrees)		Pass
2/6/21, 9:46:40 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 9:35:48 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 9:35:58 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 9:36:08 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 9:49:20 am	Powered Earth Continuity	0.14 Ohms		Pass
2/6/21, 9:49:22 am	Polarity	OK		Pass
2/6/21, 9:49:24 am	Circuit Connections	OK		Pass
2/6/21, 9:49:31 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 9:49:45 am	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 9:36:26 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 9:36:37 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass

Unit 70, Power 1 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 9:36:47 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 9:51:37 am	Powered Earth Continuity	0.39 Ohms		Pass
2/6/21, 9:51:39 am	Polarity	OK		Pass
2/6/21, 9:51:42 am	Circuit Connections	OK		Pass
2/6/21, 9:51:48 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 9:53:04 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 9:37:05 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 9:37:15 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 9:38:00 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 9:58:42 am	Powered Earth Continuity	0.25 Ohms		Pass
2/6/21, 9:58:45 am	Polarity	OK		Pass
2/6/21, 9:58:47 am	Circuit Connections	OK		Pass
2/6/21, 9:58:53 am	RCD Test	29ms at 30mA (0 degrees)		Pass
2/6/21, 9:59:27 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 9:38:20 am	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 9:38:31 am	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 9:38:41 am	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 10:35:23 am	Powered Earth Continuity	0.13 Ohms		Pass
2/6/21, 10:35:26 am	Polarity	OK		Pass
2/6/21, 10:35:30 am	Circuit Connections	OK		Pass
2/6/21, 10:35:37 am	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 10:36:01 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 71

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:50:17 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 1:50:28 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 1:50:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/6/21, 6:57:53 am	Powered Earth Continuity	0.22 Ohms		Pass
3/6/21, 6:57:56 am	Polarity	OK		Pass
3/6/21, 6:57:59 am	Circuit Connections	OK		Pass
3/6/21, 6:58:05 am	RCD Test	28ms at 30mA (0 degrees)		Pass
3/6/21, 6:58:45 am	RCD Test	33ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:51:04 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 1:51:16 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 1:51:30 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/6/21, 6:50:05 am	Powered Earth Continuity	0.17 Ohms		Pass
3/6/21, 6:50:08 am	Polarity	OK		Pass
3/6/21, 6:50:10 am	Circuit Connections	OK		Pass
3/6/21, 6:51:52 am	RCD Test	28ms at 30mA (0 degrees)		Pass
3/6/21, 6:52:58 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven				
Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:51:48 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 1:51:58 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 1:52:08 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/6/21, 6:59:17 am	Powered Earth Continuity	0.21 Ohms		Pass
3/6/21, 6:59:19 am	Polarity	OK		Pass
3/6/21, 6:59:21 am	Circuit Connections	OK		Pass
3/6/21, 6:59:28 am	RCD Test	28ms at 30mA (0 degrees)		Pass
3/6/21, 6:59:47 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Power 1				
Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:52:26 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 1:52:37 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 1:52:53 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/6/21, 7:01:43 am	Powered Earth Continuity	0.20 Ohms		Pass
3/6/21, 7:01:45 am	Polarity	OK		Pass
3/6/21, 7:01:48 am	Circuit Connections	OK		Pass
3/6/21, 7:01:53 am	RCD Test	28ms at 30mA (0 degrees)		Pass
3/6/21, 7:02:31 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Power 2				
Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:53:18 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 1:53:29 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 1:53:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/6/21, 7:05:17 am	Powered Earth Continuity	0.14 Ohms		Pass
3/6/21, 7:05:19 am	Polarity	OK		Pass
3/6/21, 7:05:22 am	Circuit Connections	OK		Pass
3/6/21, 7:05:28 am	RCD Test	28ms at 30mA (0 degrees)		Pass
3/6/21, 7:06:15 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Power 3				
Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:54:07 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 1:54:17 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 1:55:30 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/6/21, 7:07:57 am	Powered Earth Continuity	0.23 Ohms		Pass
3/6/21, 7:08:00 am	Polarity	OK		Pass
3/6/21, 7:08:02 am	Circuit Connections	OK		Pass
3/6/21, 7:08:08 am	RCD Test	28ms at 30mA (0 degrees)		Pass
3/6/21, 7:08:32 am	RCD Test	33ms at 30mA (180 degrees)		Pass
Lights				
Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:55:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 1:55:57 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 1:56:08 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
3/6/21, 7:12:06 am	Powered Earth Continuity	0.13 Ohms		Pass
3/6/21, 7:12:08 am	Polarity	OK		Pass
3/6/21, 7:12:10 am	Circuit Connections	OK		Pass
3/6/21, 7:12:16 am	RCD Test	28ms at 30mA (0 degrees)		Pass
3/6/21, 7:12:51 am	RCD Test	33ms at 30mA (180 degrees)		Pass

Unit 72

Hotplate

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 12:03:13 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 12:03:24 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 12:03:40 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 1:01:20 pm	Powered Earth Continuity	0.19 Ohms		Pass
2/6/21, 1:01:24 pm	Polarity	OK		Pass
2/6/21, 1:01:26 pm	Circuit Connections	OK		Pass
2/6/21, 1:01:34 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 1:01:46 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

A/C

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 12:04:00 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 12:04:11 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 12:06:01 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 12:24:30 pm	Powered Earth Continuity	0.15 Ohms		Pass
2/6/21, 12:24:32 pm	Polarity	OK		Pass
2/6/21, 12:24:34 pm	Circuit Connections	OK		Pass
2/6/21, 12:25:00 pm	RCD Test	23ms at 30mA (0 degrees)		Pass
2/6/21, 12:26:17 pm	RCD Test	33ms at 30mA (180 degrees)		Pass

Oven

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 12:09:06 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 12:09:17 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 12:09:35 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 1:02:07 pm	Powered Earth Continuity	0.23 Ohms		Pass
2/6/21, 1:02:09 pm	Polarity	OK		Pass
2/6/21, 1:02:11 pm	Circuit Connections	OK		Pass
2/6/21, 1:02:20 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 1:02:50 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 1

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 12:16:54 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 12:17:04 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 12:17:15 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 1:04:51 pm	Powered Earth Continuity	0.17 Ohms		Pass
2/6/21, 1:04:54 pm	Polarity	OK		Pass
2/6/21, 1:04:57 pm	Circuit Connections	OK		Pass
2/6/21, 1:05:07 pm	RCD Test	30ms at 30mA (0 degrees)		Pass
2/6/21, 1:05:37 pm	RCD Test	34ms at 30mA (180 degrees)		Pass

Power 2

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 12:17:38 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 12:17:50 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 12:18:04 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 1:08:02 pm	Powered Earth Continuity	0.16 Ohms		Pass
2/6/21, 1:08:04 pm	Polarity	OK		Pass
2/6/21, 1:08:06 pm	Circuit Connections	OK		Pass

Unit 72, Power 2 (cont.)

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 1:08:11 pm	RCD Test	28ms at 30mA (0 degrees)		Pass
2/6/21, 1:08:44 pm	RCD Test	27ms at 30mA (0 degrees)		Pass

Lights

Test Date and Time	Test	Measurement	Notes	Result
2/6/21, 12:18:26 pm	Insulation Resistance	>20 M.Ohms at 500V (A-E)		Pass
2/6/21, 12:18:36 pm	Insulation Resistance	>20 M.Ohms at 500V (N-E)		Pass
2/6/21, 12:18:47 pm	Insulation Resistance	>20 M.Ohms at 500V (A-N)		Pass
2/6/21, 1:13:47 pm	Powered Earth Continuity	0.18 Ohms		Pass
2/6/21, 1:13:50 pm	Polarity	OK		Pass
2/6/21, 1:13:52 pm	Circuit Connections	OK		Pass
2/6/21, 1:13:59 pm	RCD Test	29ms at 30mA (0 degrees)		Pass
2/6/21, 1:14:23 pm	RCD Test	33ms at 30mA (180 degrees)		Pass